

LOT COVERAGE CALCULATION

5700 SQ. FT. LOT AREA -1432 SQ. FT. -712 SQ. FT. -104 SQ. FT. FIRST FLOOR GARAGE SIDE PORCH FRONT PORCH & STAIRS −263 SQ. FT. −50 SQ. FT. EGRESS STAIR TOTAL EXISTING LOT COVERAGE 2561 SQ. FT.

TOTAL EXISTING LOT COVERAGE -2561 SQ. FT. 2850 SQ. FT. MAX. LOT COVERAGE (50%) ALLOWABLE EXPANSION 289 SQ. FT.

SQ. FOOTAGE CALCULATION

PROPOSED EXPANSION

BALANCE

TOTAL ALLOWABLE EXPANSION

FIRST FLOOR GARAGE SIDE PORCH FRONT PORCH & STAIRS EGRESS STAIR	712 104 263	SQ. FT. SQ. FT. SQ. FT. SQ. FT.
TOTAL SQUARE FOOTAGE	2561	SQ. FT.
2561 SQ. FT. (FIRST FLR,) X .8 (80%) TOTAL ALLOWABLE EXPANSION 2049 SC		SQ. FT.
2ND FLR. GARAGE SUNROOM 1ST & 2ND FLR SUNROOM DECK 3RD FLR DORMER 3RD FLR-EAST DORMER 3RD FLR-WEST DORMER 3RD FLR-STAIR DORMER 3RD FLR EAST SUNROOM FRONT PORCH 2ND FLR SIDE PORCH 2ND FLR DECK 1ST FLR	720 240 120 96 32 75 95 232 104 83	SQ. FT.
PROPOSED EXPANSION	1797	SQ. FT.

2049 SQ. FT. 1797 SQ. FT.

252 SQ. FT.

LEGEND		
SYMBOL	DESCRIPTION	
	NEW WALL	
	NEW WALL/EXISTING WALL W/INFILL	
	EXISTING WALL	
	THIN LINEWEIGHT DENOTES EXISTING CONDITIONS	
	HEAVY LINEWEIGHT DENOTES NEW CONDITIONS	
	DEMOLISHED STRUCTURE	
	EXISTING MASONRY WALL	

	NFPA LEGEND		
		EXIT LIGHT W/ DIRECTION APROW	
		FIRE EXTINGUISHER	
S	4>	EMERGENCY LIGHT	
	5	SMOKE DETECTOR W/SOUNDER BASE & STROBE (INTERCONNECTED)	
	(5)	COMBINATION CARBON MONOXUDE/ SMOKE DETECTOR W/ SOUNDER BASE & STROBE (INTERCONNECTED)	
	H	HEAT DETECTOR	
		I HR FIRE RATED PARTITION	

LIFE SAFETY NOTES

BASEMENT FLOOR PLAN

NOTE: FIRE RATED SEPARATION AT CEILING/FLOOR ASSEMBLY

& EIBC (STORAGE/MECHANICAL/UTILITY)

REQUIRED PER NFPA (MECH/UTILITY/STORAGE OVER 100 SF)

SCALE: 1/4"-1'-0"

I. THE BUILDING SHALL HAVE AN NFPA 13R FIRE SUPPRESSION SPRINKLER SYSTEM INSTALLED IN ACCORDANCE WITH NEPA IOI LIFE SAFETY CODE, 2009 INTERNATIONAL BUILDING CODE, SPRINKLER SYSTEM SHALL BE INSTALLED BY A CERTIFIED SPRINKLER CONTRACTOR AND SHALL BE REVIEWED AND APPROVED BY THE STATE OF MAINE FIRE MARSHAL AS WELL AS THE LOCAL AUTHORITY HAVING JURISPICTION, THE CONTRACTOR SHALL BEAR SOLE RESPONSIBILITY FOR THE DESIGN AND INSTALLATION OF THE SYSTEM FOR OCCUPANCY,

2. ALL ALARMS AND DETECTORS SHALL BE INTERCONNECTED WITHIN EACH LIVING UNIT.

3. REFER TO THE WINDOW SCHEDULE FOR EGRESS WINDOWS.

GENERAL NOTES

I. ALL HORIZONTAL UNIT SEPARATIONS (FLOOR/CEILING/ROOF) ASSEMBLIES SHALL BE I HR. FIRE RATED/STC 50.

2. ALL VERTICAL UNIT SEPARATIONS (TENANT WALLS) SHALL BE I HR, FIRE RATED/STC 50

3. ALL STAIR ENCLOSURES SHALL BE I HR FIRE RATED

4. ELEVATOR SHAFT ENCLOSURE SHALL BE 2 HR FIRE RATED

5. SEE SHEET AIO FOR STAIR DETAILS

6. REMOVE EXISTING DECKS & FIRE ESCAPES IN THEIR ENTIRETY.

GRANT HAYS ASSOCIATES

> ARCHITECTURE & INTERIOR DE/IGN P.O. BOX 6179 FALMOUTH MAINE 04105 207.871.5900 www.granthays.com

∫ĒAL

REVI/ION/

PROJECT MAME

BUILDING ARTMEAT

3 UNIT 162 E

∕Ħ**EE**T

19 OCT 2015 1/4"=1'-0"

JAM/MFH JOB MO.

150815

REPRODUCTION OR REU/E OF THI DOCUMENT WITHOUT WRITTEN PERMISSION FROM GRANT HAYS ASSOCIATES IS PROHIBITED.