

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

FOUSSARD JACQUES L M

Located at

85 MORNING ST

PERMIT ID: 2014-01953

ISSUE DATE: 10/15/2014

CBL: 003 A013001

has permission to **For the construction of a new, three (3) tier deck 6' x 16' on the rear of building with stairs only on first floor - no interconnecting stairway down.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

three (3) family per City Directory

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Setbacks and Footings Prior to Pouring
Foundation/Backfill
Framing Only
Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-01953	Date Applied For: 08/29/2014	CBL: 003 A013001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Three (3) Family	Proposed Project Description: For the construction of a new, three (3) tier deck 6' x 16' on the rear of building with stairs only on first floor - no interconnecting stairway down.			
Dept: Zoning Status: Approved w/Conditions Reviewer: Marge Schmuckal Approval Date: 09/10/2014 Note: R-6: 20' min. rear - showing 24.2' ; 10' min side - showing approx 13' Ok to Issue: <input checked="" type="checkbox"/>				
Conditions:				
1) It is understood that only decks are being proposed. There is no interconnecting stairway between the decks. 2) This property shall remain a three family dwelling. Any change of use shall require a separate permit application for review and approval. 3) As discussed during the review process, the property must be clearly identified prior to pouring concrete and compliance with the required setbacks must be established. Due to the proximity of the setbacks of the proposed addition, it may be required to be located by a surveyor.				
Dept: Building Status: Approved w/Conditions Reviewer: Laurie Leader Approval Date: 10/15/2014 Note: Ok to Issue: <input checked="" type="checkbox"/>				
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire Status: Approved w/Conditions Reviewer: Craig Messinger Approval Date: 10/02/2014 Note: Ok to Issue: <input checked="" type="checkbox"/>				
Conditions:				
1) All means of egress to remain accessible at all times. 2) All outstanding code violations shall be corrected prior to final inspection. 3) Shall comply with NFPA 101, Chapter 31, Existing Apartment Buildings 4) Shall meet the requirements of 2009 NFPA 1 Fire Code. 5) All construction shall comply with City Code Chapter 10.				