FD2 A-3.1 FASCIA DETAIL
SCALE: 1 1/2" = 1'-0"

FD1 A-3.1 FASCIA DETAIL
SCALE: 1 1/2" = 1'-0"

INSULATION:
- SLOPED ROOFS: R38
- WALLS: DRY DENSE PACK CELLULOSE = R21
- FLAT ROOFS (OVER HEATED SPACE): CLOSED CELL SPRAY FOAM = R49
- FOUNDATION WALLS & SLAB: 3" RIGID = R15 (AS NOTED)
- FLOORS: FULL THICKNESS SOUND ATTENUATION INSULATION (AS NOTED)
- BATHS & LAUNDRY (FLOORS & WALLS): FULL THICKNESS FIGLASS
- SEAL ALL DISSIMILAR MATERIALS WITH NON-HARDING THERMAL SEALANT PER 2009 IECC REQUIREMENTS

B1 A-1.0 BUILDING SECTION
SCALE: 1/4" = 1'-0"

REVISION: JULY 18, 2014
PERMIT SET: MAY 23, 2014

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/21/14

MARK MUELLER ARCHITECTS A.I.A.
100 Commercial Street
Suite 205
Portland, Maine 04101
Phone: 207.774.9057
Email:
rfi@muellerarchitects.com

© COPYRIGHT 2013
MARK MUELLER ARCHITECTS

PROPOSED RENOVATIONS @:
130 EASTERN PROMENADE
FOR: 130 EASTERN PROMENADE LLC
110 MARGINAL WAY
PORTLAND, MAINE 04101

BUILDING SECTIONS

REVISIONS
DATE
02.24.2011
PROJECT
130 E. PROM
DRAWN BY
MRP
CHECK BY
MLM

A-3.2