

- .060 EPDM ROOFING WHITE
- 3/4" FIR PLYWOOD KERF AS NECESSARY TO FORM COMPOUND CURVE
- 2 X 4 PT FRAMING @ 16" OC
- 2 1/2" FLASHING WITH COUNTER FLASHING BEHIND
- WRAP PT 2X6 WITH FLASHING
- 1X4 PVC TRIM
- 3/4" FIR PLYWOOD NATURAL FINISH
- 2 - 3 X 6 DOUGLAS FIR SUPPORT BEAMS
- SANDWICH STEEL 5/8" X 3 1/2" X 10 SUPPORT BLADE BETWEEN 3X6 DOUBLE BEAM
- 3 1/2" GALVANIZED STEEL SUPPORT COLUMNS W/ 7 X 7 X 5/8" 4- HOLE BASE PLATE
- 1" ROUND GALVANIZED STEEL HAND RAIL
- 3/8" X 2 GALVANIZED BAR STOCK STEEL RAILING SUPPORT
- SLOPE CAP FLASHING 1/2" TO OUTSIDE
- STANDING LOCK SEAM
- FREEDOM GRAY CAP FLASHING
- EXISTING ROOF EDGE AND FRAMING
- EXISTING 2X6 BALLOON FRAMING
- EPDM ROOF MEMBRANE DRAIN TO GUTTERS
- 3 1/2" TO 2" TAPERED RIGID INSULATION
- NEW WOOD GUTTERS
- 2" PVC DRAIN PIPES CONNECTED TO 3 - ZURN Z189 PERIMETER DRAIN SCUPPERS
- 2X4 DECK EDGE FRAMING
- EXISTING PLASTER CEILING


- FASTEN 3/4" PLYWOOD TO 2X4 SLEEPERS WITH 1/4" X 3 1/2" FASTENMASTER 3" RIGID INSULATION AND HEADLOK SCREWS 1/4 SQ FT MAX TO 2" TAPERED TO EDGE
- 1 3/4" X 3 PLYWOOD SPACER
- 1 X 8 FIR JOISTS @ 24"
- ROOF EDGE BEYOND
- NOTCH JOISTS AND SECURE WITH RECESSED 5/16" X 8" GRK STRUCTURAL SCREW
- 3/4" GALVANIZED THROUGH BOLT WITH WASHER AND 1/2" DEEP COUNTERSINK

1'-6" 2'-0"

SEE PLANS FOR SISTER FRAMING

SCATTERGOOD DESIGN
architecture + planning

80 middle street
portland, maine 04101
207-775-6141
scattergooddesign.com



90 MORNING STREET, PORTLAND, ME

title
**NORTH SOUTH
DETAIL SECTION AT BELVEDERE**

scale	3/4" = 1'-0"
date	APRIL 15 2016
project #	1304
drawn by	TST
checked by	

A 5.5
REVISED
03 / 15 / 16