


CITY OF PORTLAND  
 FIRE PREVENTION BUREAU  
 380 Congress Street, Portland, Maine 04101  
 fireprevention@portlandmaine.gov  
 (207) 874-8400



**NOTICE OF VIOLATION AND ORDER TO CORRECT**

August 25, 2017

<b>Responsible Party 1:</b> Hirst Albert 83 SEAVEY ST WESTBROOK , ME 04092		
<b>Location</b> 75 BECKETT ST	<b>CBL</b> 003 G019001	<b>Inspection Date</b> 8/8/2017
<b>Inspector</b> Robert Mcpartlan	<b>Inspection Type</b> FP Routine Inspection	<b>Status</b> Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

**You must send this form to the Fire Prevention Bureau no later than 9/15/2017.**

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
<b>NFPA 101- 7.2.1.8.1 DOORS SHALL BE SELF-CLOSING &amp; SELF-LATCHING;</b> A door leaf normally required to be kept closed shall not be secured in the open position at any time and shall be self-closing or automatic-closing in accordance with 7.2.1.8.2, unless otherwise specified by 7.2.1.8.3. Most of the Apartment doors were not self closing.	Already Completed
<b>NFPA 101- 7.1.10.2.1 DEBRIS INSIDE BUILDING;</b> No furnishings, decorations, or other objects shall obstruct exits or their access there to, egress therefrom, or visibility thereof. No storage allow in the stairways. Removal of bikes from first floor entryway	Already Completed
<b>FINAL DATE OF COMPLETED VIOLATION(S)</b>	— / — / —
<b>FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)</b>	10 / 9 / 17

Made 10 AM appt. over the phone on 9/12/17

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

**VIOLATOR CERTIFICATION**

*I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.*

*I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.*

*If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.*

9-12-17  
Date

Albert Thust  
Responsible Party

\_\_\_\_\_  
Date

\_\_\_\_\_  
Responsible Party

**SEEN AND AGREED**

9/18/17  
Date

Valerie Shea  
Fire Prevention Bureau