COPYRIGHT: Reuse or reproduction of the contents of this document is not permitted without written permission of Bild Architecture LLC

2x4 (@ 12" o.c.) porch roof framing to bear on 2x8 ledger. Ledger to be fastened to existing wall framing with Strong Tie 6" SDWH19600DB fasteners at 24" o.c. minimum.

20 A1.1 A3.1 PROPOSED SECTION

0 4'-0" SCALE: 1/4" = 1'-0"

Provide 12" wide by 2'-6" long concrete foundation wall to support 12" brick wall and preasure treated post. Provide wall to depth of 36" below grade.
Cast Strong Tie PB44 into foundation for post attachment.

10 A1.1 A3.1 PROPOSED SECTION

0 4'-0" SCALE: 1/4" = 1'-0"

RESURGAM CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 08/18/14

Bi
PO
Port
207
eva

bild ARCHITECTURE

LICENSED ARCHITECT
EVAN A. CARROLL
No. 3687
STATE OF MAINE
7/25/14

RE-ISSUED
-

PROJECT NO.
14021
PROJECT NAME
42 VESPER STREET

DRAWN BY
JHW
SHEET TITLE
SECTIONS

ISSUE DATE
7/25/14
SHEET SCALE
1/4" = 1'-0"

A

3.1