COPYRIGHT: Reuse or reproduction of the contents of this document is not permitted without written permission of Bild Architecture LLC

CITY OF PORTLAND, MAINE · RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/18/14

See Sheet A3.1 for porch attachement detail.

Provide (2) 2x8 header over window.

Railing height: 36" minimum. Railing system to be configured such that passage through by a 4" sphere is not possible at any location.

10 D1.1 P1.1 FRONT ELEVATION
0 8'-0" SCALE: 1/8" = 1'-0"

10 D1.1 P1.1 PROPOSED FRONT ELEVATION
0 8'-0" SCALE: 1/8" = 1'-0"

Existing masonry winder stairs to remain.

10 D1.1 P1.1 PROPOSED SIDE ELEVATION
0 8'-0" SCALE: 1/8" = 1'-0"

Bi
PO Por 207 eva
bild ARCHITECTURE
LICENSED ARCHITECT EVAN A. CARROLL No. 3687 STATE OF MAINE
7/25/14

PROJECT NO. 14021
PROJECT NAME 42 VESPER STREET
RE-ISSUED -
DRAWN BY JHW
SHEET TITLE ELEVATIONS
ISSUE DATE 7/25/14
SHEET SCALE 1/8" = 1'-0"

A
2.1