DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

GRIGG TIMOTHY J & RHONDA P GRIGG JTS

Located at

38 EASTERN PROMENADE

PERMIT ID: 2016-02821

ISSUE DATE: 02/16/2017

CBL: 003 K00838C

has permission to **Reconstruct existing entry steps - footprint is changing.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Laurie Leader

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

6 residential condominiums

Building Inspections

Fire Department Classification:

Apartment Building

ENTIRE

2009 NFPA 101 CH 31

PERMIT ID: 2016-02821 Located at: 38 EASTERN PROMENADE CBL: 003 K00838C

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703

or email: buildinginspections@portlandmaine.gov

Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

REQUIRED INSPECTIONS:

Setbacks and Footings Prior to Pouring Foundation/Backfill Framing Only

Final - Electric

Final - Fire

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

PERMIT ID: 2016-02821 Located at: 38 EASTERN PROMENADE CBL: 003 K00838C

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 11/01/2016 2016-02821 003 K00838C 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: **Proposed Project Description:** 6 residentail condominiums Reconstruct existing entry steps - footprint is changing. **Dept:** Zoning **Status:** Approved w/Conditions Reviewer: Ann Machado **Approval Date:** 02/02/2017 Note: R-6 Zone Ok to Issue: -reconfiguring the existing stairs - landing & stairs will be set back futher and the proposed footprintis less

Conditions:

- 1) This property shall remain as six residential condominiums. Any change of use shall require a separate permit application for review and approval.
- 2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

 Dept:
 Building Inspecti Status:
 Approved w/Conditions
 Reviewer:
 Laurie Leader
 Approval Date:
 02/16/2017

 Note:
 Ok to Issue:
 ✓

Conditions:

- 1) The concrete shall comply with IBC 2009 Ch. 19 for materials, quality control, design and construction as well as the anchoring of connected elements.
- 2) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level.

The same is required for existing buildings, where permanent wiring is feasible; or at the very least battery operated smoke detectors are required. Verification of this will be upon inspection.

- 3) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.
- 4) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 5) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

 Dept:
 Engineering DPS Status:
 Not Applicable
 Reviewer:
 Rachel Smith
 Approval Date:
 12/01/2016

 Note:
 Ok to Issue:
 ✓

Conditions:

1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 874-8801

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** Jason Grant **Approval Date:** 02/06/2017 **Note:** • Ok to Issue: ✓

Conditions:

1) All construction shall comply with City Code, Chapter 10.

All construction shall comply with 2009 NFPA 101, Chapter # 31 & 43

than what existed. - more of the stairs will be landscaped

All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).

PERMIT ID: 2016-02821 Located at: 38 EASTERN PROMENADE CBL: 003 K00838C