

354 508

Portland, Maine



Yes. Life's good here.

February 29, 2016

WENSTROM ENOCH B &

88 BECKETT ST #1

PORTLAND, ME 04101

CBL: 003 L004001

Located at 90 BECKETT ST

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

A handwritten signature in cursive script that reads "A/C Keith Gauthier".

Portland Fire Department

Fire Prevention Bureau

**CITY OF PORTLAND
PORTLAND FIRE DEPARTMENT**

380 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager WENSTROM ENOCH B &		Inspector Christopher Goodall		Inspection Date 2/26/2016
Location 90 BECKETT ST	CBL 003 L004001	Status Failed		Inspection Type Fire Company-FP Routine Inspec

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
-------------	----------------	--------------	-----------------	-------------	------------------------

1) 81.20

Violation: NFPA 10- 7.2.4.4 FIRE EXTINGUISHER INSPECTION TAG; Where manual inspections are conducted, records for manual inspections shall be kept on a tag or label attached to the fire extinguisher, on an inspection checklist maintained on file, or by an electronic method.

Notes: FIRE EXTINGUISHERS IN STAIRWELLS NEED TO BE TAGGED AND MOUNTED OR REMOVED

2) 55.20

Violation: NFPA 101- 31.3.3.2 INTERIOR FINISH; INTERIOR WALL AND CEILING FINISH MATERIALS COMPLYING WITH 10.2 SHALL BE PERMITTED AS FOLLOWS:

- (1) EXIT ENCLOSURES- CLASS A OR B
- (2) LOBBIES AND CORRIDORS- CLASS A OR B
- (3) OTHER SPACES- CLASS A, B, OR C.

Notes: PANELING USED AS WAINSCOTING ON FRONT AND REAR STAIRWELLS

3) 89.05

Violation: NFPA 1 EXCESSIVE/DISORDERLY STORAGE; REFERENCE NFPA 1 FOR EXCESSIVE FUEL-LOAD.

Notes: REAR STAIRWELL, FLOORS 2,3

Comments:

STATE OF MAINE

DISTRICT COURT
Location: Portland
Docket No.

CITY OF PORTLAND and body politic and
Corporate, located in the County of
Cumberland and State of Maine,

Plaintiff,

v.

Enoch Wenstrom
Defendant

**FIRE PREVENTION AND PROTECTION
CODE VIOLATION**


(M.R. CIV. P. 80H AND 80k)

SUMMONS NUMBER: 354508

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 04/11/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 04/11/2016.

Dated:

3/4/16



Adam R. Lee, Esq. Bar No. 4143
Associate Corporation Counsel
City of Portland
389 Congress St
Portland, ME 04101
207-874-8480