



**. . . Fire Protection by Computer Design**

Residential Fire Protection  
64 Daggett Hill Rd.  
Greene, ME 04236  
946-3473

Job Name : 65 Munjoy Street  
Building : WOOD STRUCTURE  
Location : CAR PARKING AREA (DRY SYSTEM)  
System : DRY  
Contract : 16038  
Data File : 65 Munjoy St-Car Parking-Hyd Calc.WXF

Hydraulic Design Information Sheet

Name - 65 MUNJOY STREET APT'S Date - 1/9/17  
 Location - CAR PARKING AREA (DRY SYSTEM)  
 Building - WOOD STRUCTURE System No. - DRY  
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - 16038  
 Calculated By - T. PRAY Drawing No. - 1 OF 1  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - 9'-1"  
 Occupancy - CAR PARKING

S (X) NFPA 13 ( ) Lt. Haz. Ord.Haz.Gp. (X) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 1361	System Type	Sprinkler/Nozzle
	Density	- .15	( ) Wet	Make VIKING
D	Area Per Sprinkler	- 125	(X) Dry	Model VK300
E	Elevation at Highest Outlet	- 8.58	( ) Deluge	Size 1/2"
S	Hose Allowance - Inside	-	( ) Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	( ) Other	Temp.Rat.155
G	Hose Allowance - Outside	- 250		

N Note

Calculation Flow Required - 516.12 Press Required - 32.92 AT TEST  
 Summary C-Factor Used: 100 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 7/15/1991		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 44	@ Press -	
R	Residual Press - 37	Elev. -	Well
	Flow - 503		Proof Flow
S	Elevation - 1		

P Location - HYDRANTS ARE LOCATED ON MUNJOY ST., SEE PLOT PLAN

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

E Horizontal Barriers Provided:

# Water Supply Curve (C)

Residential Fire Protection  
65 Munjoy Street


Page 2  
Date 1/5/17

## City Water Supply:

C1 - Static Pressure : 44  
C2 - Residual Pressure: 37  
C2 - Residual Flow : 503

## Demand:

D1 - Elevation : 3.283  
D2 - System Flow : 266.122  
D2 - System Pressure : 32.918  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : 250  
D3 - System Demand : 516.122  
Safety Margin : 3.740



# Fittings Used Summary

Residential Fire Protection  
65 Munjoy Street

Page 3  
Date 1/5/17

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
D	Generic Dry Pipe Valve	0	0	0	0	0	0	9.5	17	0	28	0	47	0	0	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

# Pressure / Flow Summary - STANDARD

Residential Fire Protection  
65 Munjoy Street

Page 4  
Date 1/5/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
50	8.58	5.6	11.21	na	18.75	0.15	125	7.0
51	8.58	5.6	11.37	na	18.89	0.15	125	7.0
52	8.58	5.6	11.96	na	19.37	0.15	125	7.0
53	8.58	5.6	13.23	na	20.37	0.15	125	7.0
54	8.58	5.6	15.47	na	22.02	0.15	125	7.0
55	8.58	5.6	15.82	na	22.28	0.15	125	7.0
56	8.58	5.6	11.37	na	18.88	0.15	125	7.0
57	8.58	5.6	11.54	na	19.02	0.15	125	7.0
58	8.58	5.6	12.13	na	19.51	0.15	125	7.0
59	8.58	5.6	13.42	na	20.51	0.15	125	7.0
60	8.58	5.6	15.68	na	22.18	0.15	125	7.0
61	8.58	5.6	15.27	na	21.88	0.15	100	7.0
62	8.58	5.6	16.09	na	22.46	0.15	125	7.0
70	8.58		18.51	na				
71	8.58		18.77	na				
TOR1	8.58		19.64	na				
DPV	5.0		22.93	na				
HDR1	3.5		25.02	na				
6UG	1.0		31.83	na				
TEST	1.0		32.92	na	250.0			

The maximum velocity is 14.45 and it occurs in the pipe between nodes 60 and 71

# Final Calculations - Hazen-Williams

Residential Fire Protection  
65 Munjoy Street

Page 5  
Date 1/5/17

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
50	18.75	1.682			10.000		11.210			
to		100		0.0	0.0		0.0			K Factor = 5.60
51	18.75	0.0163			10.000		0.163			Vel = 2.71
51	18.89	1.682			10.000		11.373			K Factor = 5.60
to		100		0.0	0.0		0.0			
52	37.64	0.0589			10.000		0.589			Vel = 5.43
52	19.36	1.682			10.000		11.962			K Factor = 5.60
to		100		0.0	0.0		0.0			
53	57.0	0.1270			10.000		1.270			Vel = 8.23
53	20.37	1.682			10.000		13.232			K Factor = 5.60
to		100		0.0	0.0		0.0			
54	77.37	0.2235			10.000		2.235			Vel = 11.17
54	22.03	1.682	1T	7.065	1.500		15.467			K Factor = 5.60
to		100		0.0	7.066		0.0			
70	99.4	0.3552			8.566		3.043			Vel = 14.35
	0.0									
	99.40						18.510			K Factor = 23.10
55	22.28	1.049	1T	3.568	8.500		15.824			K Factor = 5.60
to		100		0.0	3.568		0.0			
70	22.28	0.2226			12.068		2.686			Vel = 8.27
	0.0									
	22.28						18.510			K Factor = 5.18
56	18.88	1.682			10.000		11.371			K Factor = 5.60
to		100		0.0	0.0		0.0			
57	18.88	0.0165			10.000		0.165			Vel = 2.73
57	19.02	1.682			10.000		11.536			K Factor = 5.60
to		100		0.0	0.0		0.0			
58	37.9	0.0597			10.000		0.597			Vel = 5.47
58	19.51	1.682			10.000		12.133			K Factor = 5.60
to		100		0.0	0.0		0.0			
59	57.41	0.1287			10.000		1.287			Vel = 8.29
59	20.51	1.682			10.000		13.420			K Factor = 5.60
to		100		0.0	0.0		0.0			
60	77.92	0.2264			10.000		2.264			Vel = 11.25
60	22.18	1.682	1T	7.065	1.500		15.684			K Factor = 5.60
to		100		0.0	7.066		0.0			
71	100.1	0.3599			8.566		3.083			Vel = 14.45
	0.0									
	100.10						18.767			K Factor = 23.11
61	21.88	1.049	1E	2.0	3.375		15.267			K Factor = 5.60
to		120		0.0	2.000		0.0			
62	21.88	0.1537			5.375		0.826			Vel = 8.12
62	22.47	1.38	1T	4.282	8.500		16.093			K Factor = 5.60
to		100		0.0	4.282		0.0			
71	44.35	0.2092			12.782		2.674			Vel = 9.51
	0.0									
	44.35						18.767			K Factor = 10.24
70	121.67	3.26			12.500		18.510			
to		100		0.0	0.0		0.0			
71	121.67	0.0206			12.500		0.257			Vel = 4.68

# Final Calculations - Standard

Residential Fire Protection  
65 Munjoy Street

Page 6  
Date 1/5/17

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
71	144.45	3.26	1I	4.796	5.210	18.767			
to TOR1	266.12	100 0.0876		0.0 0.0	4.795 10.005	0.0 0.876		Vel = 10.23	
TOR1	0.0	3.26	1D	16.306	3.580	19.643			
to DPV	266.12	100 0.0875		0.0 0.0	16.306 19.886	1.550 1.741		Vel = 10.23	
DPV	0.0	3.26	1G	1.344	1.500	22.934			
to HDR1	266.12	120 0.0625	1T	20.159	21.503	0.650 1.437		Vel = 10.23	
HDR1	0.0	3.26	3I	20.159	7.500	25.021			
to 6UG	266.12	120 0.0624		0.0 0.0	20.159 27.659	5.083 1.727		* Fixed loss = 4 Vel = 10.23	
6UG	0.0	4.1	1L	8.72	30.000	31.831			
to TEST	266.12	140 0.0154	1G 1T	2.907 29.067	40.694 70.694	0.0 1.087		Vel = 6.47	
	250.00							Qa = 250.00	
	516.12					32.918		K Factor = 89.96	