

65 Munjoy St.: Proposed ADA Route from Sidewalk to Building.

(Potential ADA Space)

(Potential ADA Parking Space)

BORING LOCATION, TYPICAL

FINISH FLOOR ELEVATION: 130.1

0 6'
1" = 6'

SEPARATE VALVES INSTALLED IN SIDEWALK AS SHOWN FOR INDEPENDENT OPERATION OF 4" FIRE PROTECTION SERVICE AND 2" DOMESTIC WATER SERVICE. 4" LINE SHALL BE DUCTILE IRON AND 2" COPPER. ALL WORK SHALL BE IN ACCORDANCE WITH PORTLAND WATER DISTRICT STANDARDS

ELECTRIC METERS

WATER SERVICE

GAS SERVICE

