



CROSS SECTION
 1/2" = 1'-0"

SECTION A
 SECTION B

3/4" ADVANTECH FLOOR - FASTEN
 w/ 1000 PSI ADHESIVE +
 10d RING SHANK NAILS @ 16" O.C.

6" FIBERGL INSUL.
 1 HOUSE WRAP
 7/16" OSB SHEATHING
 2X6 STUDS @ 16" O.C.
 HURRICANE CLIPS

ROOF LINE - TO BE
 REMOVED
 15'-4" ±

1/2" SHEETROCK
 MATCH EXISTING
 7'-0" ±

HURRICANE CLIPS @
 EACH RAFTER

2X10 CEILING JOISTS @ 16" O.C.

2X10 RIDGE BRD
 2X8 RAFTERS @ 16" O.C.
 5/8" ADVANTECH SHEATHING
 ICE + WATER SHIELD
 2X12 RAFTERS @ 16" O.C.
 MATCH EXISTING RAFTERS

12" MATCH

16" O.C.
 2X6 STUDS

D.H. WINDOW

LVL BEAM
 (2) 1 3/4" x 11 3/8" 1/8"

2" PLG. INS.
 12"

10" ± MATCH

12"

3" ±

12"

12"