

ZONE	DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
1D001	SMOKE DETECTOR	BASEMENT	MECHANICAL ROOM	PASS
1D002	SMOKE DETECTOR	BASEMENT	HALL	PASS
1M003	SPRINKLER	BASEMENT	WATERFLOW	SEE NOTE 1
1D004	SMOKE DETECTOR	1ST	TOP OF BASEMENT STAIRS	PASS
1M005	PULL STATION	1ST	FRONT STAIRS	PASS
1D006	SMOKE DETECTOR	1ST	FRONT STAIRS	PASS
1D007	SMOKE DETECTOR	2ND	FRONT STAIRS	PASS
1M008	PULL STATION	2ND	FRONT STAIRS	PASS
1M009	TROUBLE	BASEMENT	AES RADIO	PASS
1M010	PULL STATION	BASEMENT	HALL	PASS

DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
HORN/STROBE	BASEMENT	HALL	PASS
HORN/STROBE	1ST	FRONT STAIRS	PASS
HORN/STROBE	1ST	UNIT 1 KITCHEN	PASS
MINI SOUNDER	1ST	UNIT 1 BEDROOM 1	PASS
MINI SOUNDER	1ST	UNIT 1 BEDROOM 2	PASS
HORN/STROBE	2ND	FRONT STAIRS	PASS
HORN/STROBE	2ND	UNIT 2 KITCHEN	PASS
MINI SOUNDER	2ND	UNIT 2 BEDROOM 1	PASS
MINI SOUNDER	2ND	UNIT 2 BEDROOM 2	PASS
MINI SOUNDER	2ND	UNIT 2 BEDROOM 3	PASS
HORN/STROBE	3RD	UNIT 3 LIVING ROOM	PASS
MINI SOUNDER	3RD	UNIT 3 BEDROOM 1	PASS
MINI SOUNDER	4TH	UNIT 3 BEDROOM 2	PASS

NOTES

1. TESTED BY SPRINKLER COMPANY
