

LIGHTING SYMBOL KEY

O_P PENDANT LIGHT FIXTURE

CEILING MOUNTED LIGHT FIXTURE

CEILING MOUNTED LIGHT FIX

OR RECESSED DOWN LIGHT

WALL MOUNTED LIGHT FIXTURE

O_W WALL WASHER

☐ FLUORESCENT FIXTURE

O UNDERCABINET LIGHT FIXTURE

EXIT LIGHT UNIT, WALL MOUNTED

EXIT LIGHT UNIT, CEILING MOUNTED

EMERGENCY LIGHTING

© CEILING MOUNTED EXHAUST FAN LIGHT FIXTURE COMBINATION

S CEILING MOUNTED EXHAUST FAN

TELEPHONE OUTLET

M CABLE TELEVISION / DATA OUTLET

JUNCTION BOX - "H" DENOTES RANGE HOOD "DW" DENOTES DISHWASHER

DUPLEX RECEPTACLE, MOUNT 18" A.F.F.

HALF SWITCHED DUPLEX RECEPTACLE

GROUND FAULT RECEPTACLE

REFRIDGERATOR RECEPTACLE

DUPLEX RECEPTACLE MOUNTED 42" ABOVE FINISH FLOOR

WATER-RESISTANT RECEPTACLE

DRYER OUTLET, 30 AMP, 250 VOLT, 3P. GROUNDING TYPE, FLUSH MOUNTED

\$ SINGLE POLE SWITCH

\$ THREE-WAY SWITCH

S SINGLE STATION SMOKE DETECTOR, w/ 90 db. HORN, TANDEM CONNECTION, 120 VOLT

NOTES:

 THIS IS A SCHEMATIC DESIGN FOR CONCEPT ONLY, FINAL CIRCUITRY AND INSTALLATION WILL BE THE RESPONSIBILITY OF THE INSTALLER, SUBMIT FINAL ELECTRIC DRAWINGS TO ARCHITECT PRIOR TO INSTALLATION FOR APPROVAL.

3. GROUND FAULT CIRCUIT INTERUPTOR RECEPTACLES IN BATHROOMS AND BASEMENT 4. 20 AMP CIRCUITS MINIMUM.

5. 12 GAUGE WIRE MINIMUM.

SCALE: 1/4" = 1'-0"


1 FIRST FLOOR ELECTRICAL PLAN E1.2 1/4" = 1'-0"

GENERAL NOTES (SEE G-1.1 FOR MORE GENERAL NOTES)

1 DRAWING NOTES: DRAWING NOTES LINES THEY INDIC

1. **DRAWING NOTES**: DRAWING NOTES, UNLESS THEY INDICATE OR ARE OBVIOUS, REFER TO NEW CONSTRUCTION.

2. LAYOUT: UNLESS INDICATED OTHERWISE, FLOOR PLAN DIMENSIONS ARE TO FINISH FACE OF EXISTING CONSTRUCTION AND ARE TO FACE OF FRAMING OF NEW CONSTRUCTION. DOORS AND WINDOWS ARE DIMENSIONED TO CENTERLINES OR ROUGH OPENINGS. STAIR TREAD AND RISER LAYOUT DIMENSIONS ARE TO TREAD NOSINGS.



© 2007 TFH ARCHITECT

THE ESTATES OF LONGFELLOW INN 30 EASTERN PROMENADE, PORTLAND, ME

TFH ARCHITECTS
100 COMMERCIAL STREET
PORTLAND MAINE 04101
TELEPHONE 207 775 6141

ARCHITECTURE PLANNING

CONSULTANTS:

CIVIL: Land Consulting Engineers, PA 967 Broadway South Portland, ME 04106 Tel. 207-767-7300 Fax. 1-866-207-2033

STRUCTURAL: Shelley Engineering, Inc 90 Bridge St. Suite 300 Westbrook, ME O4092 Ph.207.854.5465 ext. 19 Fax.207.854.8706

REVISIONS:

DATE: 02.14.2008
PROJECT No. 0610
DRAWN BY: SA
CHECKED BY: TST

SCALE: AS NOTED

SHEET TITLE:

1ST FLOOR

ELECTRICAL PLAN

F12