

LIGHTING SYMBOL KEY

- O_P PENDANT LIGHT FIXTURE
- CEILING MOUNTED LIGHT FIXTURE
- O_R RECESSED DOWN LIGHT
- WALL MOUNTED LIGHT FIXTURE
- O_W WALL WASHER
- ☐ FLUORESCENT FIXTURE

UNDERCABINET LIGHT FIXTURE


- EXIT LIGHT UNIT, WALL MOUNTED
- EXIT LIGHT UNIT, CEILING MOUNTED
- EMERGENCY LIGHTING
- © CEILING MOUNTED EXHAUST FAN LIGHT FIXTURE COMBINATION
- © CEILING MOUNTED EXHAUST FAN
- TELEPHONE OUTLET
- M CABLE TELEVISION / DATA OUTLET
- JUNCTION BOX "H" DENOTES RANGE HOOD "DW" DENOTES DISHWASHER
- DUPLEX RECEPTACLE, MOUNT 18" A.F.F.
- HALF SWITCHED DUPLEX RECEPTACLE
- GROUND FAULT RECEPTACLE
- REFRIDGERATOR RECEPTACLE
- DUPLEX RECEPTACLE MOUNTED 42" ABOVE FINISH FLOOR
- WATER-RESISTANT RECEPTACLE
- DRYER OUTLET, 30 AMP, 250 VOLT, 3P. GROUNDING TYPE, FLUSH MOUNTED
- \$ SINGLE POLE SWITCH
- \$ THREE-WAY SWITCH
- SINGLE STATION SMOKE DETECTOR, w/ 90 db. HORN, TANDEM CONNECTION, 120 VOLT


D WAS EN OO WATE OF FOR

1. THIS IS A SCHEMATIC DESIGN FOR CONCEPT ONLY. FINAL CIRCUITRY AND INSTALLATION WILL BE THE RESPONSIBILITY OF THE INSTALLER. SUBMIT FINAL ELECTRIC DRAWINGS TO ARCHITECT PRIOR TO INSTALLATION FOR APPROVAL.

3. GROUND FAULT CIRCUIT INTERUPTOR RECEPTACLES IN BATHROOMS AND BASEMENT 4. 20 AMP CIRCUITS MINIMUM.

5. 12 GAUGE WIRE MINIMUM.





1 SECOND FLOOR ELECTRICAL PLAN
1/4" = 1'-0"

GENERAL NOTES (SEE G-1.1 FOR MORE GENERAL NOTES)

1. DRAWING NOTES: DRAWING NOTES, UNLESS THEY INDICATE OR ARE OBVIOUS, REFER TO NEW CONSTRUCTION.

2. **LAYOUT**: UNLESS INDICATED OTHERWISE, FLOOR PLAN DIMENSIONS ARE TO FINISH FACE OF EXISTING CONSTRUCTION AND ARE TO FACE OF FRAMING OF NEW CONSTRUCTION. DOORS AND WINDOWS ARE DIMENSIONED TO CENTERLINES OR ROUGH OPENINGS. STAIR TREAD AND RISER LAYOUT DIMENSIONS ARE TO TREAD NOSINGS.

SCOTT TEAS
DO 802

© 2007 TFH ARCHITECTS

TFH ARCHITECTS
100 COMMERCIAL STREET
PORTLAND MAINE 04101
TELEPHONE 207 775 6141

ARCHITECTURE PLANNING

CONSULTANTS:

CIVIL:
Land Consulting Engineers, PA
967 Broadway
South Portland, ME 04106
Tel. 207-767-7300
Fax. 1-866-207-2033

Tel. 207-767-7300
Fax. 1-866-207-2033

STRUCTURAL:
Shelley Engineering, Inc.
90 Bridge St. Suite 300
Westbrook, ME 04092
Ph.207.854.5465 ext. 19
Fax.207.854.8706

REVISIONS:

DATE: 02.14.2008
PROJECT No. 0610
DRAWN BY: SA
CHECKED BY: TST

AS NOTED

SHEET TITLE:

2ND FLOOR
ELECTRICAL PLAN

SCALE:

E1.3