Portland, Maine



Yes, Life's good here.

February 29, 2016

MCINTYRE AUSTIN A &

325 W 5200 N

PARK CITY, UT 84660

CBL: 003 G003001

Located at 58 CONGRESS ST

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department

AC With Southerne

Fire Prevention Bureau

CITY OF PORTLAND PORTLAND FIRE DEPARTMENT

380 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager MCINTYRE AUSTIN A &				Inspector Christopher Goodall		Inspection Date 2/26/2016	
Location 58 CONGR	i	CBL 003 G	6003001	Status Failed		Inspection Type Fire Company-FP Routine Inspec	
Code	Int	/Ext	Floor	Unit No.	Area	Compliance Date	
1) 89.05 Violation :	NFPA 1 EXCESSIVE/DISORDERLY STORAGE; REFERENCE NFPA 1 FOR EXCESSIVE FUEL- LOAD.						
Notes:	FLOORS 1,2,3 IN FRONT STAIRWELL, FLOORS 2,3 REAR STAIRWELL						
2) 55.511							
Violation:	NFPA 1, CHAPTER 10 - 10.11.6 HIBACHI OR GRILL ON BALCONY; NO HIBACHI, GAS-FIRED GRILL, CHARCOAL GRILL, OR OTHER SIMILAR DEVICES USED FOR COOKING, HEATING, OROTHER PURPOSE, SHALL BE USED OR KINDLED ON ANY BALCONY OR UNDER ANY OVERHANG PORTION OR WITHIN 10 FTOF ANY STRUCTURE						
Notes:	GAS GRILL ON REAR DECK						
3) 80.37							
Violation:	NFPA 101- 8.3.4.2 60 MINUTE FIRE DOOR REQUIRED; REFER TO NFPA 101- TABLE 8.3.4.2 THAT STATES FIRE DOOR ASSEMBLIES FOR VERTICAL SHAFTS (INCLUDING STAIRWAYS, EXITS, AND REFUSE CHUTES) ARE RATED AND REQUIRED FOR 1 HOUR.						
Notes:	1ST AND 2ND FLOOR UNITS TO FRONT HALLWAY - STAIRWELL. ENTRY DOORS TO UNITS ARE RATED, BUT SECOND DOORS TO UNITS ARE NOT.						

Comments:

DISTRICT COURT Location: Portland Docket No.

CITY OF PORTLAND and body politic and Corporate, located in the County of Cumberland and State of Maine,

Plantiff,

FIRE PREVENTION AND PROTECTION CODE VIOLATION

(M.R. CIV. P. 80H AND 80k)

v.

Austin McIntyre Defendant

SUMMONS NUMBER:

354507

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 04/11/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 04/11/2016.

Dated: 3 / / / (

Adam R. Lee, Esq. Bar No. 4143 Associate Corporation Counsel City of Portland 389 Congress St Portland, ME 04101

207-874-8480