Jerome F. LaMoria Fire Chief, Fire Department

Portland Fire Department Fire Prevention Bureau 380 Congress St Portland, ME 04101

July 21, 2015

Chester O'Brion LLC 107 Congress St Portland, ME 04101

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at 22 Obrion St on 07/14/2015 revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department Fire Prevention Bureau

CITY OF PORTLAND PORTLAND FIRE DEPARTMENT

380 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager Chester O'brìon Llc				Inspector Daniel Small		Inspection Date
						7/14/2015
Location		CBL		Status		Inspection Type
0022 OBRION ST		003 0003001		Failed		Fire Prevention-FP Routine Inspe
Code	Code		Floor	Unit No.	Area	Compliance Date
1) 80.28						
Violation:	NFPA 101- 7.5.1.1 EXIT OBSTRUCTED; Where exits are not immediately accessible from an open floor area, continuous passageways, aisles, or corridors leading directly to every exit shall be maintained and shall be arranged to provide access for each occupant to not less than two exits by separate ways of travel, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4.					
Notes:	DEBRIS IN STAIRWAYS					
2) 71.25						
Violation:	NFPA 101- 31.3.4.5.1 SMOKE ALARMS REQUIRED; In buildings other than those equipped through out with an existing, complete automatic smoke detection system, smoke alarms shall be installed in accordance with 9.6.2.10, as modified by 31.3.4.5.2, outside every sleeping area in the immediate vicinity of the bedrooms and on all levels of the dwelling unit, including basements.					
Notes:						-
3) 91.30						
Violation:	NFPA 70 MISSING BREAKER IN PANEL; REFER TO NFPA 70, NATIONAL ELECTRICAL CODE, FOR INFORMATION ON MISSING BREAKERS IN AN ELECTRICAL PANEL.					
Notes:						
4) 3.011						
Violation:	NFPA 101- 31.3.2.1.1 BOILER PROTECTION REQUIRED; THE AREAS DESCRIBED IN TABLE 31.3.2.1.1 SHALL BE PROTECTED AS INDICATED: BOILER AND FUEL-FIRED HEATER ROOMS SERVING MORE THAN A SINGLE DWELLING UNIT (MINIMUM SEPARATION/PROTECTION IS 1 HOUR OR SPRINKLERS)					
Notes:						

Comments: Inspections from Naviline Fire Inspections. 9 were listed.

DISTRICT COURT Location: Portland Docket No.

CITY OF PORTLAND and body politic and Corporate, located in the County of Cumberland and State of Maine,

Plantiff,

FIRE PREVENTION AND PROTECTION CODE VIOLATION

(M.R. CIV. P. 80H AND 80k)

v.

Chester O'Brion LLC
Defendant

SUMMONS NUMBER:

353739

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 09/14/2015. I strongly urge you to contact Victoria Meserve at Fire Prevention at (207)-874-8400 or via e-mail at meserve at Fire Prevention at (207)-874-8400 or via e-mail at meserve at Fire Prevention at (207)-874-8400 or via e-mail at meserve at Fire Prevention at (207)-874-8400 or via e-mail at meserve at Fire Prevention at (207)-874-8400 or via e-mail at meserve at Fire Prevention at (207)-874-8400 or via e-mail at meserve at Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an in-person meeting to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 09/14/2015.

Dated: 8/5/15

Adam R. Lee, Esq. Bar No. 4143 Associate Corporation Council

City of Portland 389 Congress St Portland, ME 04101 207-874-8480