OVERVIEW DRAWINGS (1 OF 2)

RESURGAM, CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 12/14/15

LEGEND FOR OVERVIEW DRAWINGS

1. Air supply wall vent cap (accessory)
2. B-vent adaptor (accessory)
3. Combustion air supply piping (by others) 4" (10cm) single-wall stainless or galvanized steel sheet metal pipe with seam at top or schedule 40 PVC pipe. **Combustion air supply piping must not exceed 35 linear feet (10m)* for 40 to 125 MBTUH (12-37kW) heaters or must not exceed 40 linear feet (12m)* for 130 to 200 MBTUH (38-59kW). *Each 90° elbow inserted in the combustion air system is equivalent to 10 linear feet (3m). No more than two 90° elbows are allowed. Support as necessary.**
4. Burner without blower enclosure. Minimum clearance 12" (30cm)
5. Inlet air sleeve (accessory) with seam at top for use with outdoor air supply
6. Flexible duct (accessory)
7. Roof flashing (by others)
8. Air supply roof vent cap (accessory) must be 6" (15cm) higher than snow depth.

Legend continued on the next page.