

U-Haul Showroom New Rooftop Unit Project

Legend



Reviewed for Code Compliance
Permitting and Inspections Department
Approved with Conditions

04/23/2018

Marginal Way

New 10-ton Gas/Electric Rooftop Unit

NOTES:

1. Ducts to penetrate sidewall into show room. NOT thru roof structure.
2. Duct smoke detectors (supply and return) mounted just inside wall penetration.

Google Earth

© 2013 Google

90 ft

