SHEET NOTES:

1. ADDRESSABLE MONITOR MODULE(S) PROVIDED TO MONITOR ALL WATER FLOW, PRESSURE SWITCHES, TAMPER SWITCHES AND POST INDICATING VALVES ASSOCIATED WITH THE FIRE SPRINKLER SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).

FIRE ALARM PLAN

SCALE: 1/8"=1'-0"

0 4' 8' 16'

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 7/15/2013

RESERVED FOR CITY STAMP

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	6/5/2013

CUNNINGHAM

Security Systems

10 Princes Point Road, Yarmouth, Maine 04096

Office: 207.846.3350 • Fax: 207.846.6080

RUNNING WITH SCISSORS
250 ANDERSON STREET
PORTLAND, MAINE 04101
FIRE ALARM PLAN

DRAWN	JPB UNICAD JOB #13273
CHECKED	WAYNE B. HAWS NICET IV 90496
DATE	6/4/2013
REVISION	0
SCALE	1/8"=1'-0"

shop drawings created by:
5794 W. 4600 So.
Hooper, UT 84315
Office: 801.985.0410

UNICAD Inc.

www.unicad.net

Fire Alarm Design & Drafting Services

FA-2