CUNNINGHAM

Security Systems

10 Princes Point Road • Yarmouth, Maine 04096
(207) 846-3350 • Fax (207) 846-6080 • (800) 210-0257

RESURGAM CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/15/13

6/11/2013

Lieutenant Benjamin Wallace, Jr.
Portland Fire Department
380 Congress Street
Portland Maine 04101

Please find attached a permit application for the property located at 250 Anderson Street. The building is protected by an automatic sprinkler system and therefor, fire alarm initiation is limited to water flow, a smoke detector above the FACP, a heat detector above a kiln and manual fire alarm activation. Occupant notification is being proposed throughout the building, including, at the recommendation of the state of Maine fire Marshalls office, each individual studio space.

Thank you,

Michelle Perkins

Michelle Perkins, Operations Manager