

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

SLEEPY HOLLOW DEVELOPMENT INC /HVAC
Services, Inc.

Located at

250 ANDERSON ST

PERMIT ID: 2013-01314

ISSUE DATE: 07/01/2013

CBL: 009 A015002

has permission to **Install RTU 1-5 Trane air conditioners on roof. -Natural Gas**
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

entire building - light industrial use - artist studios

Building Inspections

Fire Department

Classification:

Business

ENTIRE

NFPA 2009

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final - Commercial

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-01314	Date Applied For: 06/25/2013	CBL: 009 A015002
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Artist Studios	Proposed Project Description: Install RTU 1-5 Trane air conditioners on roof. -Natural Gas			
Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 06/25/2013				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) The maximum permissible sound levels outlined in section 14-236(a) must be maintained..				
Dept: Building Status: Approved w/Conditions Reviewer: Tammy Munson Approval Date: 06/26/2013				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) The installation must comply with the State of Maine Gas Regulations.				
Dept: Fire Status: Approved w/Conditions Reviewer: Chris Pirone Approval Date: 06/30/2013				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Installation shall comply with NFPA 211, Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances; NFPA 31, Standard for the Installation of Oil-Burning Equipment; NFPA 54, National Fuel Gas Code; NFPA 90A, Standard for the Installation of Air-Conditioning and Ventilating Systems; NFPA 91, Standard for Exhaust Systems for Air Conveying Vapors, Gases, Mists, and Noncombustible Particulate Solids; NFPA 70, National Electrical Code; and the manufacturer's published instructions.				
2) Fuel-fired boilers shall be protected in accordance with NFPA 101, Life Safety Code.				
3) Installation shall comply with City Code Chapter 10.				