DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

ROCKINGHAM LLC

Located at

219 ANDERSON ST (Unit #4)

PERMIT ID: 2015-01791

ISSUE DATE: 11/12/2015

010 A008001 CBL:

has permission to Change of Use of Unit #4 from manufacturing to a brewery (Lone Pine Brewing Company). Install guardrail, walk-in cooler and plumbing.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Department

/s/ Craig Messinger

/s/ Jeanie Bourke

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Brewery - Unit 4

Building Inspections

Type: 2B

Factory Industrial Low Hazard -

Brewery

Occupant Load = 18

Nonsprinkled

Use Group: F-2

First Floor, Right Side

MUBEC/IBC 2009

PERMIT ID: 2015-01791 Located at: 219 ANDERSON ST (Unit #4) CBL: 010 A008001

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing
Electrical Close-in
Certificate of Occupancy/Final
Final - Electric
Fire - Change of Use Inspection
Plumbing Under Slab

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

PERMIT ID: 2015-01791 **Located at:** 219 ANDERSON ST (Unit #4) **CBL:** 010 A008001

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 2015-01791

Date Applied For: 07/24/2015

CBL:

010 A008001

Proposed Use:

Brewery (Lone Pine Brewing Company) (Unit #4)

Proposed Project Description:

Change of Use of Unit #4 from manufacturing to a brewery (Lone Pine Brewing Company). Install guardrail, walk-in cooler and plumbing.

Dept: Zoning **Status:** Approved w/Conditions **Reviewer:** Christina Stacey **Approval Date:** 09/21/2015

Note: I-Lb zone

Ok to Issue:

Brewery is an allowed use.

No off-street parking required, unit floor area is <3,000 sf No off-street loading required, operation is <5,000 sf

Conditions:

- 1) Separate permits shall be required for any new signage.
- 2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

Dept: Building Inspecti **Status:** Approved w/Conditions **Reviewer:** Jeanie Bourke **Approval Date:** 11/12/2015 **Note:** Ok to Issue: ✓

Conditions:

- 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 2) The addition of plumbing fixtures, including water lines, drainage and vent piping shall be installed in compliance with the UPC 2009 code. THE LICENSED PLUMBER SHALL CONTACT THE CITY PLUMBING INSPECTOR FOR APPROVAL OF THE DESIGN FOR THE FLOOR/TRENCH DRAIN WASTE REMOVAL SYSTEM.
- 3) Equipment shall be installed in compliance with the manufacturer's specifications and the UL listing.
- 4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

Dept: Engineering DPS **Status:** Approved w/Conditions **Reviewer:** Benjamin Pearson **Approval Date:** 10/20/2015 **Note:** Ok to Issue: ✓

Conditions:

1) A sampling point for process discharge must be provided. This access point must be separate of sanitary discharge. Please contact Ben Pearson at bnp@portlandmaine.gov or 207-874-8843.

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** Craig Messinger **Approval Date:** 10/01/2015 **Note:** Ok to Issue: ✓

Conditions:

- 1) Shall comply with NFPA 101, Chapter 40, Industrial Occupancies.
- 2) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.
- 3) Shall meet the requirements of 2009 NFPA 1 Fire Code.