

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
ROCKINGHAM LLC

Located at
219 ANDERSON ST

PERMIT ID: 2016-00944 ISSUE DATE: 06/14/2016 CBL: 010 A008001

has permission to **Change of use to Winery for the Blue Lobster Wine Co., Suite #2. Minor renovations.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Michael White

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Unit #2 - Light manufacturing - Winery (no tasting room or retail)

Building Inspections

Use Group: F-2 **Type:** 2B
Factory low-hazard - manufacturing of wine
Occupant load = 14
Building is not sprinkled
UNIT #2
MUBEC/IBC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping
Electrical Close-in w/Fire & Draftstopping
Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-00944	Date Applied For: 04/21/2016	CBL: 010 A008001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Unit #2 - Winery, will not have tasting room or retail		Proposed Project Description: Change of use to Winery for the Blue Lobster Wine Co., Suite #2. Minor renovations.		
<p>Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 05/26/2016</p> <p>Note: I-Lb zone Ok to Issue: <input checked="" type="checkbox"/></p> <p>Manufacturing space <3,000 sf, no off-street parking required.</p> <p>Conditions:</p> <p>1) This permit is not approving the unit for public retail or assembly uses such as a bar or tasting space. Any change of use or addition of new uses shall require a separate permit application for review and approval.</p> <p>2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.</p> <p>Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Laurie Leader Approval Date: 06/14/2016</p> <p>Note: Ok to Issue: <input checked="" type="checkbox"/></p> <p>Conditions:</p> <p>1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.</p> <p>2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.</p> <p>Dept: Engineering DPS Status: Approved w/Conditions Reviewer: Rachel Smith Approval Date: 06/14/2016</p> <p>Note: Ok to Issue: <input type="checkbox"/></p> <p>Conditions:</p> <p>1) If processing is to take place, a sampling point for process discharge must be provided. This access point must be separate of sanitary discharge and can be a trench drain, sump or manhole for example. A place for a sample of process waste to be taken without having sanitary in it. Please contact Rachel Smith at rms@portlandmaine.gov or 874-8833</p> <p>Dept: Fire Status: Approved w/Conditions Reviewer: Michael White Approval Date: 06/09/2016</p> <p>Note: Ok to Issue: <input checked="" type="checkbox"/></p> <p>Conditions:</p> <p>1) If applicable, all outstanding code violations shall be corrected prior to final inspection.</p> <p>2) All means of egress to remain accessible at all times.</p> <p>3) All construction shall comply with 2009 NFPA 101, Chapter 40 Industrial Occupancies.</p> <p>4) All construction shall comply with 2009 NFPA 101, Chapter 43 Building Rehabilitation.</p> <p>5) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).</p> <p>6) All construction shall comply with City Code, Chapter 10.</p>				