

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
ROCKINGHAM LLC

Located at
219 ANDERSON ST

PERMIT ID: 2017-00454 **ISSUE DATE:** 07/24/2017 **CBL:** 010 A008001

has permission to **Change of use from winery to winery with accessory tasting room/retail** provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Greg Gilbert

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Winery with accessory tasting room/retail

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final Inspection

Final - Fire

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00454	Date Applied For: 04/06/2017	CBL: 010 A008001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Winery with accessory tasting room/retail (Eighteen Twenty LLC)		Proposed Project Description: Change of use from winery to winery with accessory tasting room/retail		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 04/21/2017
Note: I-Lb zone				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) This unit shall remain a winery with accessory tasting room and retail sales. Any change of use or addition of new uses shall require a separate permit application for review and approval.				
2) In the industrial zones (I-Lb, I-L, I-M, and I-H), ancillary or accessory retail sales, food service, and events are permitted only within the limitations described in the memo titled "Definition and Scope of Uses Considered Accessory to Alcoholic Beverage Manufacturing Facilities" dated February 22, 2016, which can be found on the City's website.				
3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Greg Gilbert	Approval Date:
Note:				Ok to Issue: <input type="checkbox"/>
Conditions:				
Dept: Engineering DPS		Status: Not Applicable	Reviewer: Rachel Smith	Approval Date: 04/21/2017
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
2) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 207-874-8801.				
Dept: Fire		Status: Approved w/Conditions	Reviewer: Jason Grant	Approval Date: 05/26/2017
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) The means of egress shall be illuminated and marked in accordance with 2009 NPFA 101, sections 7.8 and 7.10. 7.8.1.3 The minimum illumination of the egress path for stairs shall be at least 10 ft-candle and the minimum illumination of the egress path of floors and other walking surfaces other than stairs shall be at least 1 ft-candle.				
2) Fire extinguishers are required per NFPA 1 (2009 Edition) Table 13.6.2. The quantity, size, type and location shall be in accordance with NFPA 1, 13.6.8. For light or ordinary hazard buildings a 2-A rated extinguisher (5lb. Dry Chemical Ext.) is required no more than 75 feet of travel distance from anywhere in the building and at least 1 extinguisher per story.				
3) All construction shall comply with City Code, Chapter 10. All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43 All construction shall comply with 2009 NFPA 1, Fire Code. This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4). All means of egress to remain accessible at all times.				