





BACKFLOW VALVE ASSEMBLY NOT TO SCALE

- BACKFLOW VALVE TO BE PROVIDED BY AGRI DRAIN CORPORATION OR AN APPROVED EQUAL.
 VALVE TO BE INSTALLED TO MANUFACTURER'S SPECIFICATIONS AND COMPLY WITH RULES AND REGULATIONS AS OUTLINED IN SECTION 2 OF THE CITY OF PORTLAND TECHNICAL MANUAL.
 VALVE SHALL BE INSTALLED WITH A VALVE BOX AND COVER TO PROVIDE EASY ACCESS AND MAINTENANCE; VALVE COVER SHALL STATE 'SEWER' ON LID FLUSH TO SURFACE. REFER TO VALVE & BOX COVER DETAIL FOR ADDITIONAL INFORMATION
- INFORMATION.

 4. CONCRETE COLLAR AT A MINIMUM 24—HOUR COMPRESSIVE STRENGTH OF 3,000 PSI.

PERMITTING NOT ISSUED FOR CONSTRUCTION

REVISION		REV. DATE
DRAWING NAME: UTILITY DETAILS - 2	PROJECT NAME: 207 ANDERSON STREET UTILITY DESIGN	LOW BALLS, LLC P.O. BOX 10250 PORTLAND, MAINE 04104
DRA		ACORN ENGINEERING, INC. 158 DANFORTH ST, PORTLAND MAINE 04102 (207) 775–2655 WITHOUT LIABILITY TO ACORN ENGINEERING, INC. THIS PLAN SHALL NOT BE MODIFIED WITHOUT WRITTEN PERMISSION FROM ACORN ENGINEERING, INC. CLIENT: CLIENT: CLIENT: CLIENT: WITHOUT LIABILITY TO ACORN ENGINEERING, INC.
CHECKE	BY: D BY: WILLIAM SAVAGE	1072 NTS OJD OJD WHS

DRAWING NO.