

ELECTRICAL PERMIT City of Portland, Me.



m/r *(circled)*

To the Chief Electrical Inspector, Portland Maine:
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical Code and the following specifications:

Date 12/10/01
Permit # 2001-5214
CBL# 010 C001

LOCATION: 151 North St METER MAKE & # _____
CMP ACCOUNT # 441-1652-060-001 OWNER ISLAND VIEW APT
TENANT _____ PHONE # _____

								TOTAL EACH FEE	
OUTLETS	1600	Receptacles	500	Switches	200	Smoke Detector	2300	.20	460.00
FIXTURES	316	Incandescent	430	Fluorescent		Strips	746	.20	149.20
SERVICES		Overhead		Underground		TTL AMPS <800		15.00	
		Overhead		Underground	1	1600 2-600 >800	3	25.00	75.00
Temporary Service		Overhead		Underground		TTL AMPS		25.00	
METERS		(number of)	71				71	1.00	71.00
MOTORS		(number of)						2.00	
RESID/COM		Electric units						1.00	
HEATING		oil/gas units		Interior		Exterior		5.00	
APPLIANCES	76	Ranges		Cook Tops		Wall Ovens		2.00	140.00
		Insta-Hot		Water heaters		Fans		2.00	
	16	Dryers	70	Disposals	70	Dishwasher	156	2.00	312.00
		Compactors		Spa		Washing Machine		2.00	
		Others (denote)						2.00	
MISC. (number of)		Air Cond/win						3.00	
		Air Cond/cent				Pools		10.00	
		HVAC		EMS		Thermostat		5.00	
		Signs						10.00	
		Alarms/res						5.00	
		Alarms/com						15.00	
		Heavy Duty(CRKT)						2.00	
		Circus/Carnv						25.00	
		Alterations						5.00	
		Fire Repairs						15.00	
	30	E Lights						1.00	30.00
		E Generators						20.00	
PANELS		Service	76	Remote		Main		4.00	304.00
TRANSFORMER		0-25 Kva						5.00	
		25-200 Kva						8.00	
		Over 200 Kva						10.00	
TOTAL AMOUNT DUE									
MINIMUM FEE/COMMERCIAL 45.00								35.00	1,541.20

INSPECTION: Will be ready _____ or will call _____

CONTRACTORS NAME Colby Electric Inc MASTER LIC. # 3630
 ADDRESS 184 Reed St Pt LIMITED LIC. # _____
 TELEPHONE 775-1380

SIGNATURE OF CONTRACTOR [Signature] \$ 3.00

ELECTRICAL INSTALLATIONS

INSPECTION: Service _____ by _____
 Service called in _____
 Closing-in 01/18/02 by WDD

Permit Number _____
 Location _____
 Owner _____
 Date of Permit _____
 Final Inspection _____
 By Inspector _____

PROGRESS INSPECTIONS: 01/18/02 BASEMENT "A"
01/25/02 1ST Floor "A"
 _____ | _____ | _____
 _____ | _____ | _____
 _____ | _____ | _____
 _____ | _____ | _____

DATE:	REMARKS:
01/18/02	(main Building) intermittent heating of building & areas where wiring is being installed. Not weather tight to date, water coming in, possible damage to (wires) due to water & cold. On the meeting w/ Greg Carde informed him of issues. Will re-inspect later date. <u>WDD</u>
01/16/02	Mench for (down hovers) okay to Brodeur <u>WDD</u>
01/25/02	Building "A" 1ST Floor only <u>WDD</u>
05/08/02	Inspection Building "A" (main building) <u>WDD</u>
05/07/02	#4 meters @ Bld. #4 only <u>WDD</u> <u>Cmp</u>
06/21/02	Final main Building only okay <u>WDD</u>