

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

WOJCIK JOSEPH B JR /lessee

Located at

184 ANDERSON ST (Bay # 1)

PERMIT ID: 2013-00901

ISSUE DATE: 06/18/2013

CBL: 010 E001001

has permission to **Installing 3 prep areas; each has 3 bay sink plus hand wash for the commercial kitchen**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
--	--

/s/ Chris Pirone

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Light Industrial uses such as winery, creamery, bakery, commercial kitchen

Building Inspections

Use Group: F-1 **Type:** 5B
Industrial - Bakery, Food Preparation
Bay #1
MUBEC/IBC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Plumbing Rough
Electrical Close-in
Final - Commercial
Final - Electric
Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-00901	Date Applied For: 05/06/2013	CBL: 010 E001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Light Industrial Uses such as commercial kitchen, bakery, creamery, winery		Proposed Project Description: Installing 3 prep areas; each has 3 bay sink plus hand wash for the commercial kitchen		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Marge Schmuckal	Approval Date: 05/13/2013
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
2) This property shall remain Light Industrial Uses such as winery, creamery, bakery and commercial kitchen. Any change of use shall require a separate permit application for review and approval.				
Dept: Building		Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 06/18/2013
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Approval of City license is subject to health inspections per the Food Code.				
2) Approval is subject to compliance with City and State Food Codes per the Portland Public Health Dept.				
3) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
4) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire		Status: Approved w/Conditions	Reviewer: Chris Pirone	Approval Date: 06/02/2013
Note:		Ok to Issue: <input type="checkbox"/>		
Conditions:				
1) Installation shall comply with City Code Chapter 10. All construction shall comply with City Code Chapter 10. http://www.portlandmaine.gov/citycode/chapter010.pdf				