

Income Property Management

August 20, 2015

Portland Maine
Jonathan Rioux
389 Congress St
Portland Maine 04101

RE: 184 Anderson St Bay #1 Portland Maine
Urban Farm Fermentory Renovation


This letter is to make sure that all requirements you need done is completed for a full Occupancy permit and completed by September 13, 2015.

1. Spoke to Kaplan Thompson Architects, bay 2 is F-2 Factory Low Hazard and he is not requiring handrails this area is a loading dock.
2. Craig Messenger requirement outside hook up on sprinkler.
3. Two interior doors taken down in tasting room.
4. Old tasting room and bar not in use now used as bulk storage.
5. Two doors have signs emergency exit only, storage area no exit.
6. One toilet bay# 1 make ADA compliant.

Please let me know if I am missing anything on your list.

If you have any questions please call 773-4206.

Very Truly Yours



Joseph B Wojcik Jr.

P.O. Box 15444 Portland Maine 04101 773-4206 Fax 761-1908