

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

EAST BAYSIDE STUDIOS LLC

Located at

170 ANDERSON ST (Unit #2)

PERMIT ID: 2015-01720

ISSUE DATE: 09/08/2015

CBL: 010 E002001

has permission to **Change the Use and renovate tenant space, Unit #2, (3,552 SF). New walls, doors, finishes and kitchenette. The work includes new office space and a retail area accessory to the overall production space for "Zootility Tools".**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Unit 2 - light industiral - tool manufacturing

Building Inspections

Use Group: F-1 **Type:** 3B
Factory - Moderate Hazard - Zootility
Tool Manufacturing
Occupant Load = 31 (actual 12-18)
NFPA 13 Sprinkler System
First Floor
MUBEC/IBC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Electrical Close-in

Certificate of Occupancy/Final

Final - Electric

Fire - Change of Use Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-01720	Date Applied For: 07/17/2015	CBL: 010 E002001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Light industrial - manufacture of small tools.		Proposed Project Description: Change the Use and renovate tenant space, Unit #2, (3,552 SF). New walls, doors, finishes and kitchenette. The work includes new office space and a retail area accessory to the overall production space for "Zootility Tools".		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 08/14/2015
Note: I-Lb Zone		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) This permit is being approved with the condition that the retail component is accessory to the principal use of tool manufacturing.				
2) Separate permits shall be required for any new signage.				
3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 09/03/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Engineering DPS		Status: Not Applicable	Reviewer: Benjamin Pearson	Approval Date: 07/21/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov				
Dept: Fire		Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 08/25/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) A separate Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.				
2) All outstanding code violations shall be corrected prior to final inspection.				
3) Shall comply with NFPA 101, Chapter 40, Industrial Occupancy				
4) Shall meet the requirements of 2009 NFPA 1 Fire Code.				
5) All construction shall comply with City Code Chapter 10.				

PERMIT ID: 2015-01720

Located at: 170 ANDERSON ST (Unit #2)

CBL: 010 E002001