CITY OF PORTLAND, MAINE · RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/26/16

DOOR & DOOR FRAME SCHEDULE

DOOR NO.		DOOR SIZE (WIDTH x HEIGHT x THICKNESS)	DOOR STYLE	FRAME STYLE	LOCK FUNCTION	DOOR & FRAME HARDWARE	CLOSER	LABEL (MINUTES)	REMARKS
FIRST LEVEL DOORS									
101	EXISTING	3'-0" X 7'-0" X 1 3/4"	FULL GLASS	HOLLOW METAL	PUSH/PULL WITH DEADBLOT	CLOSER	1	–	
101A	REPLACEMENT	2'-8" X 6'-8" X 1 1/2"	SOLID CORE WOOD	SOLID WOOD	PASSAGE	1 PAIR SPRING HINGES		20 MINUTE	* REPLACE EXISTING DOOR FOR FIRE RATING
102	EXISTING	3'-0" X 7'-0" X 1 3/4"	FULL GLASS DIVIDED LITE	HOLLOW METAL	PUSH / PULL – NO LATCH	CLOSER		–	
103	EXISTING	3'-0" X 7'-0" X 1 3/4"	BIFOLD	HOLLOW METAL	DUMMY (PULL)			–	
104	EXISTING	3'-0" X 7'-0" X 1 3/4"	6 PANEL HOLLOW CORE	HOLLOW METAL	PRIVACY LEVER			–	
108	EXISTING	3'-0" X 7'-0" X 1 3/4"	FLUSH INSULATED STEEL	HOLLOW METAL	STOREROOM LEVER HARDWARE	CLOSER	1	–	
109	NEW	12'-0" X 12'-0"	GLAZED OVERHEAD DOOR	NONE	STANDARD LOCKING OVERHEAD			–	
110	NEW	12'-0" X 12'-0"	GLAZED OVERHEAD DOOR WITH ACCESSIBLE EGRESS DOOR	NONE	STANDARD LOCKING OVERHEAD PLUS STOREROOM LEVER AT PASS DOOR	CLOSER AT PASS DOOR	1	–	OPERATING MECHANISM TO LIMIT OPEN HEIGHT AT 8'-0" WITH HIGH-LIFT TRACK
***	NEW *	3'-0" X 7'-0" X 1 3/4"	FLUSH INSULATED STEEL	HOLLOW METAL	STOREROOM LEVER HARDWARE	* RESERVED DOOR HEADING IN THE EVENT THAT DOOR 110 IS NOT PROVIDED WITH A PASS DOOR			
SECOND LEVEL DOORS									
201	EXISTING	2'-8" X 6'-8" X 1 1/2"	FULL GLASS WOOD	SOLID WOOD	ENTRANCE LOCK KNOB *			–	* REPLACE KNOB HARDWARE WITH LEVER
202	EXISTING	3'-0" X 7'-0" X 1 3/4"	–	–	PASSAGE LEVER			–	
203	EXISTING	3'-0" X 7'-0" X 1 3/4"	HOLLOW WOOD	SPLIT JAMB WOOD	PRIVACY			–	
204	EXISTING *	3'-0" X 7'-0" X 1 3/4"	FIRE CORE STEEL	HOLLOW METAL	PASSAGE LEVER	CLOSER	1	90	RELOCATE EXISTING MECHANICAL ROOM DOOR, FRAME AND HARDWARE

GENERAL NOTES:

1. SEE FLOOR PLANS FOR TOTAL NUMBER OF DOORS

A5 BUILDING SECTION

CWS ARCHITECTS
ARCHITECTURE | INTERIOR DESIGN
PLANNING + DESIGN
CONSTRUCTION SERVICES

DESIGNER

LICENSED ARCHITECT GEORGE G. LAVIGNE No. 3114 STATE OF MAINE

CWS ARCHITECTS
ARCHITECTURE | INTERIOR DESIGN
434 CUMBERLAND AVENUE
PORTLAND, MAINE 04101
T: 207.774.4641
F: 207.774.4016
WWW.CWSARCH.COM

OWNER

MOUGALIAN RUGS

SCARBOROUGH, MAINE 04174

PROJECT

175 ANDERSON STREET
CHANGE OF USE

175 ANDERSEN STREET
PORTLAND, MAINE 04101

DRAWING

SCHEMATIC BUILDING AND STAIR SECTION

DOOR SCHEDULE

CWS PROJECT NUMBER: 16.036

REVISIONS

DRAWING NUMBER
A 5.01

SCALE: SCALE: 1/4" = 1'-0"
DATE: 07/14/2016