DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

FLETCHER-RITTER LLC /Green Leaf Construction -Ben Wentling

PERMIT ID: 2013-01018 **ISSUE DATE:** 06/26/2013 **CBL:** 010 H004001

D 11 11 T

has permission to Change of use from Art studios to a personal training studio with accessory offices (chiropractory & naturopath)

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED. A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Jeanie Bourke

Located at

50 COVE ST

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

. .

Approved Property Use - Zoning

recreational use (personal fitness with accessory uses) and light industrial artists and warehousing

| Building Inspect | Fire Department | | |
|-------------------------------------|-----------------|--|--|
| Use Group: B | Type: 5B | | |
| Business - Personal 50 occupants | | | |
| First Floor Front Lef | ît | | |
| MUBEC/IBC 2009 | | | |

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY) or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing Electrical Close-in Above Ceiling Inspection Final - Electric Certificate of Occupancy/Final Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

| City of Portland, Maine - Building or Use Permit | | | Permit No: | Date Applied For: | CBL: | | | |
|---|--|---------|----------------------|-------------------|--|--|--|--|
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-87 | | | 2013-01018 | 05/20/2013 | 010 H004001 | | | |
| Proj | posed Use: Pr | roposed | Project Description: | | | | | |
| To change the use of part of the light industrial art uses to Personal training studio with accessory offices Some artist studio remain and warehousing remains Change of use from Art studios to a personal training studio with accessory offices Some artist studio remain and warehousing remains | | | | | | | | |
| D | ept: Zoning Status: Approved w/Conditions Review | ewer: | Marge Schmucka | 1 Approval Da | ate: 05/21/2013 | | | |
| Note: Ok to Issue: 🗹 | | | | | | | | |
| | Conditions:1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work. | | | | | | | |
| 2) | 2) This property shall remain light industrial artists studios and warehousing and recreational pitness training studio with accessory uses with the issuance of this permit and subsequent issuance of a certificate of occupancy. Any change of use shall require a separate permit application for review and approval. | | | | | | | |
| 3) | Separate permits shall be required for any new signage. | | | | | | | |
| | ept: Building Status: Approved w/Conditions Reviewed | ewer: | Jeanie Bourke | Approval Da | ate: 06/26/2013 Ok to Issue: ✓ | | | |
| | onditions: | | | | | | | |
| 1) | Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. | | | | | | | |
| 2) | Penetrations through fire resistance rated assemblies shall be protected by an approved penetration firestop system installed as tested in accordance with ASTM E814 or UL 1479 | | | | | | | |
| 3) | 3) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. | | | | | | | |
| | ept:FireStatus:Approved w/ConditionsRevieote:Notified GC of NFPA questions. | ewer: | Chris Pirone | Approval Da | ate: 06/05/2013 Ok to Issue: ☑ | | | |
| С | onditions: | | | | | | | |
| 1) | Any cutting and welding done will require a Hot Work Permit from | Fire D | epartment. | | | | | |
| 2) | 2) Application requires State Fire Marshal approval. | | | | | | | |
| 3) | Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer. Contact Michelle Sweeney at 874-8682 for further information. | | | | | | | |
| 4) | 4) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation. | | | | | | | |
| 5) | Compliance with NFPA 1, Fire Code, Annex O for In-building Public Safety Radio Enhancement Systems shall be verified by an RF Engineer. | | | | | | | |
| 6) | 6) A separate Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation. | | | | | | | |
| 7) | 7) Fire department connection type and location shall be approved in writing by Fire Prevention Bureau. | | | | | | | |
| 8) | 8) A firefighter Building Marking Sign is required. | | | | | | | |
| 9) | 9) Fire extinguishers are required per NFPA 1. | | | | | | | |
| 10 | 10 Construction or installation shall comply with City Code Chapter 10. | | | | | | | |
| 11 | 1 Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve. | | | | | | | |

- 12 Fire walls, fire barriers, fire partitions, smoke barriers and smoke partitions or any other wall required to have protected openings or penetrations shall be effectively and permanently identified with signs or stenciling in accessible concealed floor, floor-ceiling or attic spaces at intervals not exceeding 30 feet with lettering not less than 0.5 inches in height.
- 13 Notice: The first scheduled final inspection fee is at no charge. Additional inspections shall be billed at \$75 for each inspector.
- 14 Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.
- 15 **The fire alarm system design shall be evaluated for the renovated areas by an NICET IV certified interior fire alarm designer or a licensed engineer for compliance with the code. A compliance letter is required prior to the final inspection.** **A current inspection sticker from an approved fire alarm inspection company is required prior to the final inspection.**
- 16 All means of egress to remain accessible at all times.