

CUNNINGHAM

Security Systems

10 Princes Point Road • Yarmouth, Maine 04096
(207) 846-3350 • Fax (207) 846-6080 • (800) 210-0257

September 10, 2013

Attn: Captain Christopher Pirone
Fire Prevention Bureau
Portland Fire Department
380 Congress Street
Portland, ME 04101
Fax#: (207) 874-8410

Dear Captain Pirone,

This letter is to inform you that on September 3, 2013, we completed the installation, programming and testing of the new fire alarm devices added to the existing building fire alarm control panel located in the building at 50 Cove Street, Portland, ME. These new devices were installed, programmed and test to NFPA 72 standards with signals sent to and received at our central monitoring station. These new devices were found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,



Ronald S. Sneider, Manager

cc: Acct. File