

Application And Notes, If Any, Attached

# PERMIT

Permit Number: 10110 - 8 2010

This is to certify that SLEEPY HOLLOW DEVELOPMENT INC. Construction  
has permission to "Portland Power Yoga" 1st floor interior renovations tenant fit-  
out 72 COVE ST 1st floor CE 010 H007002

City of Portland

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in his department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is lathed or otherwise red-in. 24 HOUR NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

### OTHER REQUIRED APPROVALS

Fire Dept. CHIEF R. Lanthier  
Health Dept. \_\_\_\_\_  
Appeal Board \_\_\_\_\_  
Other \_\_\_\_\_  
Department Name

Carrie Burke 10/7/10  
Director - Building & Inspection Services

**PENALTY FOR REMOVING THIS CARD**

**City of Portland, Maine - Building or Use Permit Application**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 10-1140	Issue Date:	CBL: 010 H007002
-----------------------	-------------	---------------------

Location of Construction: 72 COVE ST 1st floor	Owner Name: SLEEPY HOLLOW DEVELOPME	Owner Address: PO BOX 465	Phone:
Business Name: Portland Power Yoga	Contractor Name: Daigle Construction	Contractor Address: 234 Church Rd. Brunswick	Phone 2077251452
Lessee/Buyer's Name	Phone:	Permit Type: <i>change of use</i> Alterations - Commercial	Zone: ILB

Past Use: Commercial <del>Portland Power Yoga</del>	Proposed Use: Commercial "Portland Power Yoga" 1st floor interior renovations - tenant fit-up <i>new eq 4,752</i> <i>for "recreational center"</i>	Permit Fee:	Cost of Work: \$0.00	CEO District: 1 <i>(recreation)</i>
Proposed Project Description: "Portland Power Yoga" 1st floor interior renovations - tenant fit-up <i>for "recreational center"</i>		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied <i>" See Conditions"</i>	INSPECTION: Use Group <i>B w/ Accessory</i> Type: <i>5B</i> <i>IBX-2003</i>	
		Signature: <i>(RG)</i>	Signature: <i>JMB 10/1/10</i>	

PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		
Action:	<input type="checkbox"/> Approved	<input type="checkbox"/> Approved w/Conditions
Signature:	Date:	

Permit Taken By: ldobson	Date Applied For: 09/10/2010	<b>Zoning Approval</b>		
-----------------------------	---------------------------------	------------------------	--	--

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..</p>	<p>Special Zone or Reviews</p> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> Major <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Denied	<p>Zoning Appeal</p> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	<p>Historic Preservation</p> <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied
	<p><b>PERMIT ISSUED</b></p> <p>OCT - 8 2010</p> <p>City of Portland</p>	<p><i>ok with conditions</i></p> <p>Date: <i>9/20/10</i></p>	<p>Date:</p>

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT ADDRESS DATE PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE DATE PHONE



# CITY OF PORTLAND, MAINE

Department of Building Inspections

## Original Receipt

600 \$ 2010

Received from Chris Doyle

Location of Work 74 Casco

Cost of Construction \$ \_\_\_\_\_ Building Fee: \_\_\_\_\_

Permit Fee \$ \_\_\_\_\_ Site Fee: \_\_\_\_\_

Certificate of Occupancy Fee: 75.00

Total: \_\_\_\_\_

Building (IL) \_\_\_\_\_ Plumbing (IS) \_\_\_\_\_ Electrical (I2) \_\_\_\_\_ Site Plan (U2) \_\_\_\_\_

Other \_\_\_\_\_

CEL: 124 010 11007002

Check #: Visa Total Collected \$ 75.00

**No work is to be started until permit issued. Please keep original receipt for your records.**

Taken by: Doyle

WHITE - Applicant's Copy  
YELLOW - Office Copy  
PINK - Permit Copy



# CITY OF PORTLAND

Department of Building

## Original Receipt

7-10-10

Received from

Portland Park Assoc  
2200 SE St.

Amount of Contribution \$ \_\_\_\_\_ Building Fee: \_\_\_\_\_

Permit Fee \$ \_\_\_\_\_ Site Fee: \_\_\_\_\_

Certificate of Occupancy Fee: \_\_\_\_\_

Tax: 4/10

Building (BL) \_\_\_\_\_ Plumbing (15) \_\_\_\_\_ Electrical (22) \_\_\_\_\_ Site Plan (17)

Other \_\_\_\_\_

CR: 10-H-7

Check #: 1015 Total Collected 4,830

No work is to be started until permit issued.  
Please keep original receipt for your records.

Taken by: SPH

WHITE - Applicant's Copy  
YELLOW - Office Copy  
PINK - Permit Copy

**City of Portland, Maine - Building or Use Permit**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 10-1140	Date Applied For: 09/10/2010	CBL: 010 H007002
-----------------------	---------------------------------	---------------------

Location of Construction: 72 COVE ST 1st floor	Owner Name: SLEEPY HOLLOW DEVELOPME	Owner Address: PO BOX 465	Phone:
Business Name: Portland Power Yoga	Contractor Name: Daigle Construction	Contractor Address: 234 Church Rd. Brunswick	Phone: (207) 725-1452
Lessee/Buyer's Name	Phone:	Permit Type: Change of Use - Commercial	

Proposed Use: Commercial "Portland Power Yoga" 1st floor interior renovations - tenant fit-up - 4,752 sq ft	Proposed Project Description: "Portland Power Yoga" 1st floor interior renovations - tenant fit-up
--	---

Dept: Zoning      Status: Approved with Conditions      Reviewer: Marge Schmuckal      Approval Date: 09/20/2010  
 Note: Ok to Issue:   
 1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.  
 2) Separate permits shall be required for any new signage.  
 3) The approved use for the Portland Power Yoga is for a recreational center use. Any future change of use requires a separate review and approval.

Dept: Building      Status: Approved with Conditions      Reviewer: Jeanine Bourke      Approval Date: 10/07/2010  
 Note: 10/5/10 Routed from Tammy M. Ok to Issue:   
 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.  
 2) This is a change of use per zoning to a recreational facility, however per building code the architect classified it as Business use with accessory Assembly area. The assembly area will be separated from the adjacent tenant business. State the CO as Business (recreation).  
 3) Application approval based upon information provided by applicant. Any deviation from approved plans requires separate review and approval prior to work.

Dept: Fire      Status: Approved with Conditions      Reviewer: Capt Keith Gautreau      Approval Date: 09/21/2010  
 Note: Ok to Issue:   
 1) All construction shall comply with City Code Chapter 10.  
 2) This permit is being approved on the basis of the plans submitted. Any deviation from the plans would require amendments and approval.  
 3) Emergency lights are required to be tested at the electrical panel on the same circuit as the lighting for the area they serve.  
 4) Installation of a Fire Alarm system requires a Knox Box to be installed per city ordinance  
 5) The fire alarm system shall comply with the City of Portland Standard for Signaling Systems for the Protection of Life and Property. All fire alarm installation and servicing companies shall have a Certificate of Fitness from the Fire Department.  
 6) The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.  
 7) Occupancies with an occupant load of 100 persons or more require panic hardware on all doors serving as a means of egress.  
 8) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit.  
 9) Fire extinguishers required. Installation per NFPA 10  
 10) No means of egress shall be affected by this renovation

<b>Location of Construction:</b> 72 COVE ST 1st floor	<b>Owner Name:</b> SLEEPY HOLLOW DEVELOPME	<b>Owner Address:</b> PO BOX 465	<b>Phone:</b>
<b>Business Name:</b> Portland Power Yoga	<b>Contractor Name:</b> Daigle Construction	<b>Contractor Address:</b> 234 Church Rd. Brunswick	<b>Phone</b> (207) 725-1452
<b>Lessee/Buyer's Name</b>	<b>Phone:</b>	<b>Permit Type:</b> Change of Use - Commercial	

**Comments:**

9/17/2010-mes: did not receive a parking plan - called the contractor and he will get back to me. ALSO FRONT STAFF DID NOT CHARGE FOR A CHANGE OF USE CERTIFICATE OF OCCUPANCY PERMIT - GET BEFORE ISSUING

9/20/2010-mes: received a plot plan showing parking for 47 vehicles - needs to show only 12 for this change of use

10/4/2010-dlh: received revised plans, per Jeanne. /gg

10/7/2010-jmb: Spoke to Matt P. To verify the use classification, it will be B with accessory A. Separation rating will be installed between the assembly and adjacent tenant business. Cannot locate the revised plans, he will resubmit.

## **BUILDING PERMIT INSPECTION PROCEDURES**

**Please call 874-8703 or 874-8693 (ONLY )  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspection Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months, if the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue with construction.**

  **X**   **Framing/Rough Plumbing/Electrical: Prior to Any Insulating or drywalling**

  **X**   **Final/Certificate of Occupancy: Prior to any occupancy of the structure or use.**

**NOTE: There is a \$75.00 fee per inspection at this point.**

**The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OR CIRCUMSTANCES.**

**IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.**



# General Building Permit Application

If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Address of Construction: 72 COVE STREET			
Total Square Footage of Proposed Structure 4,752 SQ. FT (TENANT SPACE)		Square Footage of Lot N/A	
Tax Assessor's Chart, Block & Lot Chart# 010 Block# H007 Lot# 002		Owner: SLEEPY HOLLOW DEVELOPMENT INC 183 MIDDLE STREET PORTLAND, MAINE 04101	Telephone: 207.774.4737
Lessee/Buyer's Name (If Applicable) PORTLAND POWER YOGA 425 MARGINAL WAY PORTLAND, ME 04101 P: 207.761.4382		Applicant name, address & telephone: MARK MUELLER ARCHITECTS 100 COMMERCIAL ST. - SUITE 205 PORTLAND, ME 04101 P: 207.774.9057 - F: 207.773.3851	Cost Of Work: \$ 181,000  Fee: \$ 1,830  C of O Fee: \$ N/A
Current Specific use: BUSINESS If vacant, what was the previous use? N/A Proposed Specific use: BUSINESS			
Project description: INTERIOR RENOVATIONS - TENANT FIT-UP <i>PowerYoga - Approved AS A "recreation Center"</i>			
Contractor's name, address & telephone: DAIGLE CONSTRUCTION CO			
Who should we contact when the permit is ready: CRAIG DAIGLE Mailing address: DAIGLE CONSTRUCTION CO. Phone: 207.751.2751 234 CHURCH ROAD BRUNSWICK, MAINE 04011			

RECEIVED

*CO Fee Added in UI Due prior to issuance.*

Please submit all of the information outlined in the City of Portland Building Department's Building Permit Application Manual. Failure to do so will result in the automatic denial of your application.

In order to be sure the City fully understands the full scope of your project, you may be required to provide request additional information prior to the issuance of a permit. For more information, please visit [www.portlandmaine.gov](http://www.portlandmaine.gov), stop by the Building Inspections Department, or call 207.774.4737.

I hereby certify that I am the Owner of record of the named property, or that I have been authorized by the owner to make this application as his/her authorized agent. I understand that I have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the permit. I shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the permit.

Signature of applicant:

*Mark Mueller*

Date:

SEP 08, 2010

This is not a permit; you may not commence ANY work until the permit is issued.





CITY OF PORTLAND  
BUILDING CODE CERTIFICATE  
389 Congress St., Room 315  
Portland, Maine 04101

### ACCESSIBILITY CERTIFICATE

Designer: MARK MUELLER ARCHITECTS

Address of Project: 72 COVE STREET

Nature of Project: INTERIOR TENANT RENOVATIONS. TENANT FIT-UP

The technical submissions covering the proposed construction work as described above have been designed in compliance with applicable referenced standards found in the Maine Human Rights Law and Federal Americans with Disability Act.

Signature: 

Title: ARCHITECT

Firm: MARK MUELLER ARCHITECTS

Address: 100 COMMERCIAL STREET  
SUITE 205  
PORTLAND, ME 04101

Phone: 207.774.9057



**NOTE: If this project is a new Multi Family Structure of 4 units or more, this project must also be designed in compliance with the Federal Fair Housing Act. On a separate submission, please explain in narrative form the method of compliance.**



CITY OF PORTLAND  
BUILDING CODE CERTIFICATE  
389 Congress St., Room 315  
Portland, Maine 04101

TO: Inspector of Buildings City of Portland, Maine  
Department of Planning & Urban Development  
Division of Housing & Community Service

FROM: MARK MUELLER ARCHITECTS

RE: Certificate of Design


DATE: SEPTEMBER 08, 2010

These plans and / or specifications covering construction work on:

INTERIOR TENANT RENOVATIONS. TENANT FIT-UP

Have been designed and drawn up by the undersigned, a Maine registered Architect / Engineer according to the 2001 International Building Code and local amendments.

(SEAL)



Signature: *Mark Mueller*

Title: ARCHITECT


Firm: MARK MUELLER ARCHITECTS

As per Maine State Law:

\$50,000.00 or more in new construction, repair expansion, addition, or modification for Building or Structures, shall be prepared by a registered design Professional.


Address: 100 COMMERCIAL STREET  
SUITE 205  
PORTLAND, ME 04101






Descriptor/Area
A: 082 2789 sqft
B: 045 6320 sqft
C: OVRHD DR-MTR-OP-WD-MT 168 sqft
D: 045 3515 sqft
E: 083 900 sqft
F: OVRHD DR-MTR-OP-WD-MT 120 sqft
G: OVERHEAD DR-WOOD/MTL 100 sqft
H: SPRINKLER SYS WET 13524 sqft
I: 1S 3515 sqft
J: 1S 6320 sqft
K: 1S 2789 sqft

$13,524 \div 400 = 33.81$   
 $34 \text{ pkgs for total}$   
 $4752 \div 100 = 47.52$   
 $47 \text{ pkgs}$   
8772



AREA OF NEW WORK

KEY PLAN  
SCALE: 1/16"=1'-0"



EXISTING & DEMO PLAN  
SCALE: 1/16"=1'-0"

WALL LEGEND

EXISTING WALL	—————
NEW WALL	—————
FIRE RATED WALL	—————
1 HOUR	—————
EXISTING WALL TO BE REMOVED	- - - - -



MARK  
MUELLER  
ARCHITECTS  
AIA

120 Commercial Street  
Portland, ME 04101  
Phone: 603.773.4887  
Fax: 603.773.4887  
www.muellerarchitects.com

INT. RENOVATIONS & TENANT FIT-UP:  
**Portland Power Yoga**  
72 COVE STREET  
PORTLAND, MAINE

EXISTING & DEMO FLOOR PLAN  
PLEASE SEE NOTES, PLAN ENVELOPE,  
SCHEDULE & SPEC.

REVISED: SEPTEMBER 20, 2010  
FIRE MARSHAL PERMIT SET: SEPTEMBER 15, 2010

D-1.0



# DOOR SCHEDULE

## DOOR SCHEDULE ABBREVIATIONS

S.C. - SOLID CORE  
 MTL. - METAL  
 DIVLT. - DIVIDED LITE  
 EXIST. - EXISTING DOOR  
 FLUSH - FLUSH  
 H.M. - HOLLOW METAL

DOORS					FRAMES					REMARKS
NO	TYPE	SIZE	THK.	F.R.	MAT.	TYPE	MAT.	F.R.	DETAILS HEAD JAMB	
100	-	ETR	-	-	ETR	-	ETR	-		EXISTING ENTRY DOOR TO REMAIN - PANIC HARDWARE
101	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE
102	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE
103	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE
104	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE
105	-	3068	1 1/2"	-	MTL.	-	H.M.	-		NEW METAL STORE FRONT ENTRY DOOR SYSTEM
106	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE
107	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE
108	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE
109	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE, KICK PLATE
110	-	3068	1 1/2"	-	WOOD	-	H.M.	-		PUSH/PULL, CLOSER, KICK PLATE
111	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE
112	-	3068	1 1/2"	-	WOOD	-	H.M.	-		PUSH/PULL, CLOSER, KICK PLATE
113	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE
114	-	4068	1 1/2"	-	WOOD	-	H.M.	-		PUSH/PULL W/ LEVER HARDWARE
115	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE
116	-	3068	1 1/2"	-	WOOD	-	H.M.	-		PANIC HARDWARE
117	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE
118	-	3068	1 1/2"	-	WOOD	-	H.M.	-		LEVER HARDWARE, CLOSER
119	-	3068	1 1/2"	-	WOOD	-	H.M.	-		PANIC HARDWARE, CLOSER
120	-	3068	1 1/2"	-	WOOD	-	H.M.	-		PANIC HARDWARE, CLOSER


- NOTE:  
 1. ALL NEW DOOR HARDWARE SHALL MEET THE REQUIREMENTS OF THE ADA & BE LEVER HANDLE.  
 FINISH SHALL BE BRUSHED CHROME OR BRUSHED STAINLESS.  
 2. EXISTING & NEW DOORS TO BE RE-KEYED TO REQUIREMENTS OF TENANT.  
 3. G.C. TO COORDINATE SECURITY SYSTEM W/ TENANT REQUIREMENTS.  
 4. G.C. TO PROVIDE NEW HARDWARE.  
 5. ALL DOORS & FRAMES SHALL BE PAINTED, COLOR T.B.D. BY TENANT.  
 6. DOOR STYLE T.B.D. BY TENANT.

### NFPA 101 CODE DATA


OCCUPANT LOAD	114 PEOPLE
USE GROUP CLASSIFICATION	BUSINESS
TYPE OF CONSTRUCTION	5000 - UNPROTECTED
ACTUAL BUILDING AREA	4,321 TENANT SPACE
FIRE DEPRESSION	EXISTING TO REMAIN
STAIR ENCLOSURES	N/A
SHAFTS	N/A
EXIT ACCESS CORRIDORS	N/A
INTERIOR LOAD BEARING WALLS	N/A
STRUCTURAL MEMBER SUPPORTING WALL	N/A
FLOOR CONSTRUCTION	N/A
ROOF CONSTRUCTION	N/A
GENERAL NOTES	

### IBC 2003 CODE DATA


OCCUPANT LOAD	114 PEOPLE
USE GROUP CLASSIFICATION	BUSINESS
TYPE OF CONSTRUCTION	5000 - UNPROTECTED
TENANT SPACE AREA	4,321 SF
STREET FRONTAGE INCREASE (1200) - 80 FT	N/A
AUTOMATIC SPRINKLER SYSTEM (OR CASE 2000) - 80 FT	10,000 G.P. & 4 STORIES
FLORIDA BUILDING AREA - 80 FT	1,000 SF
BUILDING HEIGHT	1 STORY
FIRE DEPRESSION	EXISTING TO REMAIN
STAIR ENCLOSURES	N/A
SHAFTS	N/A
EXIT ACCESS CORRIDORS	N/A
INTERIOR LOAD BEARING WALLS	N/A
STRUCTURAL MEMBER SUPPORTING WALL	N/A
FLOOR CONSTRUCTION	N/A
ROOF CONSTRUCTION	N/A
GENERAL NOTES: OCCUPANT LOAD	
BUSINESS - 100 SQ GROSS PERSON (1,200 SF) - 11 PEOPLE	
ASSEMBLY - 15 SQ NET PERSON (1,200 SF) - 10 PEOPLE	
TOTAL OCCUPANT LOAD = 114 PEOPLE	
INTERIOR FINISHES	
WALLS & CEILING CLASS A, B, OR C	
FLOOR CLASS 1 OR 2	
F.F.E. SHALL MEET NFPA 263 & 701	





RESTROOM INT. ELEVATIONS  
 SCALE: 1/2"=1'-0"



ENLARGED H.C. SHOWER PLAN  
 SCALE: 1/2"=1'-0"



ENLARGED H.C. BATH PLAN  
 SCALE: 1/2"=1'-0"



DI STORE FRONT DETAIL  
 A-1.0 SCALE: 1/2"=1'-0"

REVISED: SEPTEMBER 20, 2010  
 FIRE MARSHAL PERMIT SET: SEPTEMBER 15, 2010



MARK  
 MUELLER  
 ARCHITECTS  
 A.I.A.

1300 Commercial Street  
 Suite 100  
 Portland, Maine 04101  
 Phone: 207.774.8817  
 Fax: 207.774.8811  
 E-Mail: info@markmueller.com  
 Web: www.markmueller.com

© 2010 Mark Mueller Architects, Inc.

Portland Power Yoga  
 72 COVE STREET  
 PORTLAND, MAINE

DETAILS & SCHEDULES

A-1.1