

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

SLEEPY HOLLOW DEVELOPMENT INC

Located at

72 Cove St (84R)

PERMIT ID: 2015-00609

ISSUE DATE: 05/15/2015

CBL: 010 H007002

has permission to **Change of Use from Warehouse to Taxi Repair Service and Distpatch - 84 R Cove Street (right rear unit) - ASAP Taxi**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

right rear unit (84 R) - taxi repair & dispatch

Building Inspections

Use Group: S-2/B **Type:** 3B

Storage Moderate Hazard - Taxi repair and dispatch

Business - Taxi dispatch

Non-sprinkled

First floor (84R)

MUBEC/IBC2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-00609	Date Applied For: 03/30/2015	CBL: 010 H007002
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Taxi Repair and Service Dispatch (ASAP Taxi)		Proposed Project Description: Change of Use from Warehouse to Taxi Repair Service and Distpatch - 84 R Cove Street (right rear unit) - ASAP Taxi		
<hr/>				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 04/28/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Separate permits shall be required for any new signage.				
<hr/>				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 05/15/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This is a Change of Use ONLY permit. It does NOT authorize any construction activities.				
<hr/>				
Dept: Engineering DPS	Status: Not Applicable	Reviewer: Benjamin Pearson	Approval Date: 05/15/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note: May need oil/water separator				
Conditions:				
<hr/>				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 05/13/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Shall comply with NFPA 101, Chapter 39, Existing Business Occupancies.				
2) All outstanding code violations shall be corrected prior to final inspection.				
3) Shall meet the requirements of 2009 NFPA 1 Fire Code.				