CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 03/29/17

Existing rafters are rough sawn 2x6 roughly at 16" O.C. sistered to 2x12. There are collar ties on each of the sistered rafters. The roof is sheathed with 1" rough sawn pine. The roofs surface material is a Everlast standing seam metal roof with metals clips up every 12"

Per Applicant 03/27/2017