

Inspection Services
Michael J. Nugent
Manager



Housing & Neighborhood Services
Mark B Adelson
Director

CITY OF PORTLAND

November 1, 2001

David Lloyd
48 Union Wharf
Portland, ME 04101

RE: 145 Anderson St. (012 B005)

Dear David,

Thank you for the information with regard to the above project. I am enclosing Section 1705.1.1 of the BOCA Code (1999). It requires that the statement of special inspection include a complete list of materials and work requiring special inspections, the inspections to be performed and a list of the individuals, approved agencies and firms intended to be retained for conduction such inspections. Please forward this report for review. With regard to the reply to items 1 and 2, please forward the fire resistance and sound transmission ratings for the dwelling unit separations, both wall and floor/ceiling/roof assemblies, this must comply with the 1999 BOCA Code. We will review the other information that you have provided.

Sincerely,

Mike Nugent
Manager of Inspection Services