DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

150 WASH AVE LLC

Located at

150 WASHINGTON AVE

PERMIT ID: 2018-00077

ISSUE DATE: 02/08/2018

CBL: 012 D016001

has permission to Condo conversion

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Brian Stephens

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

Three residential condominium units

Use Group: R-2

Type: 5B

Classification:

Residential Apartment House (3 Units)

Apartment Building

Non-Sprinkled

ENTIRE

FNTIRF

NFPA 101 CH 31

MUBEC/IBC-2009

PERMIT ID: 2018-00077 Located at: 150 WASHINGTON AVE CBL: 012 D016001

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703

or email: buildinginspections@portlandmaine.gov

Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final Inspection

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

PERMIT ID: 2018-00077 **Located at:** 150 WASHINGTON AVE **CBL:** 012 D016001

City of Portland, Maine - Building or Use Permit		Termit No.	Date Applied For.	CDL.
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 87	4-8716	2018-00077	01/18/2018	012 D016001
Proposed Use:	Proposed	Project Description:		
3 unit condominium	conversion			
Dept: Zoning Status: Approved w/Conditions Re	viewer:	Christina Stacey	Approval Da	nte: 02/05/2018

Donnit No.

Data Applied Fore

✓

Ok to Issue:

Conditions:

Note:

- 1) This property shall remain three residential condominium units. Any change of use shall require a separate permit application for review and approval.
- 2) Tenants who have vacated the property within the last six months may still be entitled to the rights enumerated in Article VII of the City's Chapter 14 Land Use Ordinance.

 Dept:
 Building Inspecti Status:
 Approved w/Conditions
 Reviewer:
 Brian Stephens
 Approval Date:
 02/05/2018

 Note:
 Ok to Issue:
 ✓

Conditions:

- 1) Window sills in locations more than 72 inches from finished grade shall be a minimum of 24 inches above the finished floor of the room, unless a window fall prevention devices is installed in accordance with section IRC Sec. R612.3 or IBC Sec. 1405.13.2.
- 2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 3) Per IBC Sec. 3401.3 for existing buildings and dwelling units, compliance with smoke, carbon monoxide, fire protection and safety systems and devices shall be per City Ordinance Chapter 10 and NFPA 101
- 4) Egress size windows are required (1) in each sleeping room per IRC Sec. R310 or per the State Fire Marshal policies for existing buildings.
- 5) The continuity of the fire resistance rated wall or floor/ceiling assembly shall be installed and maintained as described in IBC Ch. 7.
- 6) This permit recognizes a pre-existing use and does not require or certify compliance with the City's current building code. The inspection performed will be done pursuant to the City's Minimum Standards for Housing, The Housing Code. All violations shall be corrected prior to the final inspection and the issuance of the Certificate of Occupancy.
- 7) The issuance of this permit shall not be construed to be a permit for, or approval of, any violations of any of the provisions of the building code or of any other ordinance of this jurisdiction.
- 8) This permit authorizes a change in ownership only. Construction activity was not applied for or reviewed as a part of this permit.
- 9) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

 Dept:
 Fire
 Status:
 Approved w/Conditions
 Reviewer:
 Jason Grant
 Approval Date:
 02/08/2018

 Note:
 Ok to Issue:
 ✓

Conditions:

1) Every sleeping and living area in a residential occupancy shall have at least 1 primary means of escape and 1 secondary means of escape. The secondary means of escape may be an outside egress window operable from the inside without the use of tools, keys or special effort. Egress windows shall provide a clear opening of not less than 5.7 Sq. Ft. The width shall not be less than 20 inches, and height shall not be less than 24 inches. The bottom of the window opening shall not be more than 44 inches above the floor. The opening shall also meet the other requirement of NFPA 101 section 24.2.2.3.3.

- 2) City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas.

 1. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
 - 2.On each level of the dwelling unit, including basements but excluding attics and crawl spaces.
- 3) City of Portland Code Chapter 10 section 10-3 (i) all new smoke alarm must use photoelectric technology. In existing apartment building smoke detectors must be powered by the buildings electrical service and must have a secondary power source (battery). Smoke Alarms shall be installed per NFPA 101 2009 section 9.6.2.10. Detectors are required to be installed in the following locations
 - 1.Inside all sleeping rooms.
 - 2. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
 - 3.On each level of the dwelling unit, including basements but excluding attics and crawl spaces.
- 4) All construction shall comply with City Code, Chapter 10.
 - All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43 and other applicable chapters
 - All construction shall comply with 2009 NFPA 1, Fire Code.
 - This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).
 - All means of egress to remain accessible at all times.
 - If applicable, all outstanding code violations shall be corrected prior to final inspection.

PERMIT ID: 2018-00077 **Located at:** 150 WASHINGTON AVE **CBL:** 012 D016001