



GENERAL NOTES
 1. REFER TO DRAWING E300 FOR TYPICAL UNIT PANEL.
 2. CONTRACTOR SHALL WIRE EF-4 FOR CONTINUOUS LOW SPEED OPERATION WITH RAMP UP WHEN RECIRC HOOD IS TURNED ON. REFER TO MANUFACTURERS WIRING DIAGRAM.

FOURTH FLOOR PLAN
 SCALE: 1/4"=1'-0"

<p>BENNETT ENGINEERING <small>REGISTERED PROFESSIONAL ENGINEER LICENSE #0688</small></p>	Prepared For:
<p>ARCHETYPE architects <small>48 Union Wharf Portland, Maine 04101 (207) 772-6022 Fax (207) 772-4056</small></p>	Consulting Engineer:
Project:	134 WASHINGTON AVENUE 1 FOLEY FARM ROAD SCARBOROUGH, MAINE
Revisions:	10/17/14 - BID SET
Date:	Oct. 17, 2014
Scale:	As Noted
FOURTH FLOOR POWER PLAN	
<h1>E304</h1>	