

From: Chris Pirone
To: DMP@portlandmaine.gov; JF@portlandmaine.gov; JLT@portlandmaine.gov;
JST@portlandmaine.gov; MES@portlandmaine.gov; Thomas.Errico@tylin.com;
DSenus@woodardcurran.com
CC: AMACHADO@portlandmaine.gov; BAB@portlandmaine.gov
Date: 12/4/2013 10:34 AM
Subject: Re: Munjoy Heights: Final submission for Dec 17th PB Hearing

Fire comments:

How will the units be numbered for 911 address purposes?
If needed a meeting should be set up with Fire and 911 officer.

The 20' access needs to be maintained at all times. This includes no parking (fire lane) and snow removal plan. These conditions should be placed in the condo documents.
I understand this is a European street style and there will be different pavement styles but is to remain flush and able to withstand the weight of Fire Department Vehicles. As an example a fire department ladder truck sets its aerial ladder to the roof, it needs to deploy its outriggers to the edge of the access road, and road will be able to support this load.

Captain Chris Pirone
Portland Fire Department
Fire Prevention Bureau
380 Congress Street
Portland, ME 04101
(t) 207.874.8405
(f) 207.874.8410