

March 4, 2014

MUNJOY HEIGHTS - FIREWALL REVISIONS

1.) REVISE exterior wall type to 1 hr fire rated wall meeting (UL# U326) for a distance from 2hr fire wall intersection to 48" out on wall. This requires revising the interior GWB from 5/8" to 5/8" 'type-x' GWB, and revising the exterior sheathing from Fire retardant treated plywood to standard combustibile sheathing. See IBC 2009 section 706.5 exception #1.

This revision applies to:

- (sheet A1-1A, A1-2A column line C-1)
- (sheet A1-1B, A1-2B, A1-3B column lines C-1, C-2, E-1 and E-2)
- (sheet A1-1C, A1-2C, A1-3C column lines B-1, D-1)
- (sheet A1-1C column lines B-2, D-2)
- (sheet A1-1D, A1-2D, A1-3D column lines C-1)
- (sheet A1-1D, column line C-2)
- (sheet A1-1E column line B-2)
- (sheet A1-2B, A1-3B column lines C-1, E-1)
- (sheet A1-2C column lines B-1, D-1)
- (sheet A1-2E column lines B-1, D-1)
- (sheet A1-1FA column lines C-1, C-2, E-1, E-2)
- (sheet A1-2FA column lines C-1, E-1)

2.) REVISE exterior wall sheathing from Fire Retardant Treated Plywood as shown on plans to standard combustibile sheathing at intersection of 1hr Fire Partitions

This revision applies to:

- (sheet A1-0A column line B-3)
- (sheet A1-1A, A1-2A column lines B-1, B-3 and C-3)
- (sheet A1-0B column lines B-2, D-2 and F-2)
- (sheet A1-1B, A1-2B, A1-3B column lines B-1, B-2, D-1, D-2, F-1, F-2)
- (sheet A1-0C column lines C-2 and E-2)
- (sheet A1-1C, A1-2C, A1-3C column lines B-2, C-1, C-2, D-2, E-1, E-2)
- (sheet A1-0D, column lines B-2 and D-2)
- (sheet A1-1D, A1-2D, A1-3D, column lines B-1, B-2, D-1, D-2)
- (sheet A1-0E, column lines C-2, E-2)
- (sheet A1-1E, A1-2E column lines C-1, C-2, E-1, E-2)
- (sheet A1-2B, A1-3B column lines C-2, E-2)
- (sheet A1-2C, A1-3C column lines B-2, D-2)
- (sheet A1-2D, A1-3C column line C-2)
- (sheet A1-2E column lines B-2, D-2)
- (sheet A1-0FA column lines B-2, D-2)
- (sheet A1-0FB column line F-2)
- (sheet A1-1FA column lines B-1, B-2, D-1, D-2)
- (sheet A1-1FB column lines F-1, F-2)
- (sheet A1-1FB column lines B-1, B-2, C-2, D-1, D-2, E-2)
- (sheet A1-2FB column lines F-1, F-2)

207-650-6414

senatorearchitecture.com

ryan@senatorearchitecture.com

565 Congress St, Suite 304

Portland, Maine 04101

3.) REVISE exterior wall sheathing from Fire Retardant Treated Plywood as shown on plans to 1/2" Densglas 'Type-X' non-combustible exterior sheathing at intersection of 2hr Fire Wall to 48" out each side.

This revision applies to:

- (sheet A1-0A, column line C-3)
- (sheet A1-0B, column lines C-2 and E-2)
- (sheet A1-0C, column lines B-2 and D-2)
- (sheet A1-0D, column line C-2)
- (sheet A1-0E column lines B-2, D-2)
- (sheet A1-1E column lines B-1, D-1, D-2)
- (sheet A1-0FA column lines C-2, E-2)

207-650-6414

senatorearchitecture.com

ryan@senatorearchitecture.com

565 Congress St, Suite 304

Portland, Maine 04101

