

Jeanie Bourke - Re: Munjoy Heights - Firewalls

From: Jeanie Bourke
To: Ryan Senatore
Date: 3/5/2014 12:40 PM
Subject: Re: Munjoy Heights - Firewalls

Hi Ryan,

Per our conversation yesterday you agreed to submit these revisions on the plans, which I just received. I just wanted to reply to this email with the correction on #2 from non-combustible to combustibile as I want to include this email with the approved documents.

Thanks,
Jeanie

Jeanie Bourke
CEO/LPI/Plan Reviewer

City of Portland
Planning & Urban Development Dept./ Inspections Division
389 Congress St. Rm 315
Portland, ME 04101
jmb@portlandmaine.gov
Direct: (207) 874-8715
Office: (207) 874-8703

>>> Ryan Senatore <ryan@senatorearchitecture.com> 3/4/2014 2:54 PM >>>
Jeanie,

See the attached fire wall revision list based on the info below, as well as a cut sheet for the densglas.

- 1.) We are revising the 2hr wall intersections to 1hr fire rated exterior walls with combustibile sheathing for 48 out from the fire wall per 706.5 ex 1
- 2.) We are revising the 1 hr fire partition intersections to combustibile sheathing and non fire rated.
- 3.) At locations where the 2 hr fire walls have doors and windows within 48" we are using non-combustibile sheathing per 706.5 ex 3

Thanks,

Ryan Senatore, AIA LEED-AP BD+C
Maine Licensed Architect
RYAN SENATORE ARCHITECTURE
207-650-6414
ryan@senatorearchitecture.com
www.senatorearchitecture.com