

HYDRAULIC DESIGN INFORMATION SHEET

Name - Munjoy heights Date - 2-21-14
Location - second floor
Building - A System No. - 1 of 1
Contractor - Residential Fire Protection Contract No. - C14005
Calculated By - JAL Drawing No. - 1 of 7
Construction: (X) Combustible () Non-Combustible Ceiling Height 9'-5"
OCCUPANCY - Residential

S Type of Calculation: ()NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 10.6 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - 100 Gpm Make Viking Model VK486
I Elevation at Highest Outlet - Feet Size 1/2" K-Factor 4.0
G Note:Safety Margin: 14.792 Temperature Rating
N

Calculation Gpm Required 155.748 Psi Required 48.065 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 11-7-13 Rated Cap. Cap.
T Time of Test - 12:35 PM @ Psi Elev.
E Static (Psi) - 63 Elev.
R Residual (Psi) - 58 Other Well
Flow (Gpm) - 1061 Proof Flow Gpm
S Elevation - 0

P Location:

P
L Source of Information:
Y

Water Supply Curve (C)

Residential Fire Protection
Munjoy Heights building A


Page 2
Date 2-21-14

City Water Supply:

C1 - Static Pressure : 63
C2 - Residual Pressure: 58
C2 - Residual Flow : 1061

Demand:

D1 - Elevation : 12.343
D2 - System Flow : 55.748
D2 - System Pressure : 48.065
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 155.748
Safety Margin : 14.792



Fittings Used Summary

Residential Fire Protection
Munjoy Heights building A

Page 3
Date 2-21-14

Fitting Legend

| Abbrev. | Name | 1/2 | 3/4 | 1 | 1 1/4 | 1 1/2 | 2 | 2 1/2 | 3 | 3 1/2 | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|--------------------------|-----|-----|---|-------|-------|----|-------|----|-------|----|----|----|----|----|----|----|----|----|-----|-----|
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| F | 45' Elbow | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 3 | 3 | 4 | 5 | 7 | 9 | 11 | 13 | 17 | 19 | 21 | 24 | 28 |
| G | Generic Gate Valve | 0 | 0 | 0 | 0 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| N | CPVC 90'El Harvel-Spears | 7 | 7 | 7 | 8 | 9 | 11 | 12 | 13 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| O | CPVC Tee - Branch | 3 | 3 | 5 | 6 | 8 | 10 | 12 | 15 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| T | 90' Flow thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Z | Generic Flow Switch | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |

Pressure / Flow Summary - STANDARD

Residential Fire Protection
Munjoy Heights building A

Page 4
Date 2-21-14

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| 1 | 28.5 | 4 | 14.84 | na | 15.41 | 0.1 | 130 | 10.6 |
| 2 | 28.5 | 4 | 11.12 | na | 13.34 | 0.1 | 130 | 10.6 |
| 3 | 28.5 | 4 | 12.2 | na | 13.97 | 0.1 | 130 | 10.6 |
| 4 | 28.5 | 4 | 10.6 | na | 13.02 | 0.1 | 130 | 10.6 |
| 13 | 0.0 | | 25.12 | na | | | | |
| 12 | 0.0 | | 25.42 | na | | | | |
| 11 | 0.0 | | 25.75 | na | | | | |
| 10 | 0.0 | | 28.16 | na | | | | |
| 15 | 0.0 | | 28.49 | na | | | | |
| 16 | 0.0 | | 29.56 | na | | | | |
| 17 | 0.0 | | 30.06 | na | | | | |
| 26 | 0.0 | | 30.1 | na | | | | |
| 27 | 0.0 | | 30.59 | na | | | | |
| 28 | 0.0 | | 34.5 | na | | | | |
| TR | 1.0 | | 34.82 | na | | | | |
| BR | 5.0 | | 39.72 | na | | | | |
| UNG1 | 0.0 | | 44.02 | na | 100.0 | | | |
| TEST | 0.0 | | 48.06 | na | | | | |

The maximum velocity is 13.59 and it occurs in the pipe between nodes 11 and 15

Final Calculations - Hazen-Williams

Residential Fire Protection
Munjoy Heights building A

Page 5
Date 2-21-14

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. | Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------------|-----------------|------------------------|-----------------------|--------------------|----------------------------|---------------------------|----------------|-------|-------------------------------|-------|
| 1 to 10 | 15.41 15.41 | 1.101 150 0.0420 | 1N 1O | 7.0 5.0 0.0 | 11.250 12.000 23.250 | 14.844 12.343 0.977 | | | K Factor = 4.00 Vel = 5.19 | |
| | 0.0 15.41 | | | | | | 28.164 | | K Factor = 2.90 | |
| 2 to 11 | 13.34 13.34 | 0.874 150 0.0990 | 1N 1O | 7.0 3.0 0.0 | 13.000 10.000 23.000 | 11.125 12.343 2.278 | | | K Factor = 4.00 Vel = 7.13 | |
| | 0.0 13.34 | | | | | | 25.746 | | K Factor = 2.63 | |
| 3 to 12 | 13.97 13.97 | 1.101 150 0.0350 | 1O 1N | 5.0 7.0 0.0 | 13.000 12.000 25.000 | 12.201 12.343 0.876 | | | K Factor = 4.00 Vel = 4.71 | |
| | 0.0 13.97 | | | | | | 25.420 | | K Factor = 2.77 | |
| 4 to 13 | 13.02 13.02 | 0.874 150 0.0947 | 1O 1N | 3.0 7.0 0.0 | 13.000 10.000 23.000 | 10.600 12.343 2.179 | | | K Factor = 4.00 Vel = 6.96 | |
| 13 to 12 | 0.0 13.02 | 1.101 150 0.0307 | | 0.0 0.0 0.0 | 9.700 0.0 9.700 | 25.122 0.0 0.298 | | | Vel = 4.39 | |
| 12 to 11 | 13.98 27.0 | 1.101 150 0.1185 | | 0.0 0.0 0.0 | 2.750 0.0 2.750 | 25.420 0.0 0.326 | | | Vel = 9.10 | |
| 11 to 15 | 13.34 40.34 | 1.101 150 0.2491 | 1O | 5.0 0.0 0.0 | 6.000 5.000 11.000 | 25.746 0.0 2.740 | | | Vel = 13.59 | |
| | 0.0 40.34 | | | | | | 28.486 | | K Factor = 7.56 | |
| 10 to 15 | 15.41 15.41 | 1.101 150 0.0419 | 1O | 5.0 0.0 0.0 | 2.680 5.000 7.680 | 28.164 0.0 0.322 | | | Vel = 5.19 | |
| 15 to 16 | 40.34 55.75 | 1.394 150 0.1437 | | 0.0 0.0 0.0 | 7.500 0.0 7.500 | 28.486 0.0 1.078 | | | Vel = 11.72 | |
| 16 to 26 | -27.88 27.87 | 1.598 150 0.0205 | 2O | 16.0 0.0 0.0 | 10.000 16.000 26.000 | 29.564 0.0 0.533 | | | Vel = 4.46 | |
| | 0.0 27.87 | | | | | | 30.097 | | K Factor = 5.08 | |
| 16 to 17 | 27.87 27.87 | 1.598 150 0.0205 | | 0.0 0.0 0.0 | 24.000 0.0 24.000 | 29.564 0.0 0.492 | | | Vel = 4.46 | |
| 17 to 27 | 0.0 27.87 | 1.598 150 0.0205 | 2O | 16.0 0.0 0.0 | 10.000 16.000 26.000 | 30.056 0.0 0.532 | | | Vel = 4.46 | |
| | 0.0 27.87 | | | | | | 30.588 | | K Factor = 5.04 | |

Final Calculations - Standard

Residential Fire Protection
Munjoy Heights building A

Page 6
Date 2-21-14

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------------|--------------|----------------------|-----------------------------|-------------------------|------------------|----------------|------------------|-------|-------|
| 26 to 27 | 27.87 | 1.598 150 | 0.0 | 24.000 | 30.097 | 0.0 | | | |
| 27 to 28 | 27.87 | 0.0205 | 0.0 | 24.000 | 0.491 | 0.0 | Vel = | 4.46 | |
| 27 to 28 | 27.88 | 1.598 150 | 1N 9.0 0.0 | 44.000 9.000 | 30.588 0.0 | 0.0 | | | |
| 28 to TR | 55.75 | 0.0739 | 0.0 | 53.000 | 3.916 | 0.0 | Vel = | 8.92 | |
| 28 to TR | 0.0 | 2.067 120 | 2E 10.0 1T 10.0 | 3.500 20.000 | 34.504 -0.433 | 0.0 | | | |
| TR to BR | 55.75 | 0.0319 | 0.0 | 23.500 | 0.749 | 0.0 | Vel = | 5.33 | |
| TR to BR | 0.0 | 2.067 120 | 1E 5.0 1Z 5.0 | 10.000 10.000 | 34.820 4.268 | 0.0 | * Fixed loss = 6 | | |
| BR to UNG1 | 55.75 | 0.0319 | 0.0 | 20.000 | 0.637 | 0.0 | Vel = | 5.33 | |
| BR to UNG1 | 0.0 | 1.92 150 | 1T 10.55 0.0 | 60.000 10.550 | 39.725 2.166 | 0.0 | | | |
| UNG1 to TEST | 55.75 | 0.0302 | 0.0 | 70.550 | 2.131 | 0.0 | Vel = | 6.18 | |
| UNG1 to TEST | 100.00 | 8.27 140 | 1T 55.354 1G 6.326 | 110.000 118.616 | 44.022 4.000 | 0.0 | Qa = 100 | | |
| TEST | 155.75 | 0.0002 | 4F 56.936 | 228.616 | 0.043 | 0.0 | * Fixed loss = 4 | | |
| | 0.0 | | | | | 0.0 | Vel = | 0.93 | |
| | 155.75 | | | | 48.065 | | K Factor = | 22.47 | |