

HYDRAULIC DESIGN INFORMATION SHEET

Name - Munjoy heights Date - 2-21-14
Location - Third floor
Building - D System No. - 1 of 1
Contractor - Residential Fire Protection Contract No. - C14005
Calculated By - JAL Drawing No. - 4 of 7
Construction: (X) Combustible () Non-Combustible Ceiling Height 9'-5"
OCCUPANCY - Residential

S Type of Calculation: ()NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 10.6 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - 100 Gpm Make Viking Model VK486
I Elevation at Highest Outlet - Feet Size 1/2" K-Factor 4.0
G Note:Safety Margin: 11.580 Temperature Rating
N

Calculation Gpm Required 151.477 Psi Required 51.283 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 11-7-13 Rated Cap. Cap.
T Time of Test - 12:35 PM @ Psi Elev.
E Static (Psi) - 63 Elev.
R Residual (Psi) - 58 Other Well
Flow (Gpm) - 1061 Proof Flow Gpm
S Elevation - 0

P Location:
P
L Source of Information:
Y

Water Supply Curve (C)

Residential Fire Protection
Munjoy Heights building D


Page 2
Date 2-21-14

City Water Supply:

C1 - Static Pressure : 63
C2 - Residual Pressure: 58
C2 - Residual Flow : 1061

Demand:

D1 - Elevation : 21.655
D2 - System Flow : 51.477
D2 - System Pressure : 51.283
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 151.477
Safety Margin : 11.580



Fittings Used Summary

Residential Fire Protection
Munjoy Heights building D

Page 3
Date 2-21-14

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N	CPVC 90'El Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

Residential Fire Protection
Munjoy Heights building D

Page 4
Date 2-21-14

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	50.0	4	7.6	na	11.03	0.1	110	7.6
1A	50.0		9.18	na				
2	50.0	4	8.67	na	11.78	0.1	110	7.6
2A	50.0		9.46	na				
3	40.0	4	12.59	na	14.19	0.1	130	10.6
4	40.0	4	13.1	na	14.48	0.1	130	10.6
10	50.0		10.47	na				
11	50.0		9.67	na				
11A	50.0		10.07	na				
12	50.0		11.31	na				
13	50.0		12.02	na				
14	50.0		12.48	na				
23	50.0		12.66	na				
24	50.0		12.79	na				
33	50.0		12.97	na				
34	50.0		13.43	na				
35	50.0		16.49	na				
TR	5.0		36.63	na				
BR	0.0		45.34	na				
UNG1	0.0		47.18	na	100.0			
TEST	0.0		51.28	na				

The maximum velocity is 10.82 and it occurs in the pipe between nodes 12 and 13

Final Calculations - Hazen-Williams

Residential Fire Protection
Munjoy Heights building D

Page 5
Date 2-21-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1	11.03	0.824			11.250	7.600				
to		120		0.0	0.0	0.0				K Factor = 4.00
1A	11.03	0.1402		0.0	11.250	1.577				Vel = 6.64
1A	0.0	1.049	2N	14.0	16.000	9.177				
to		120		0.0	14.000	0.0				
10	11.03	0.0433		0.0	30.000	1.298				Vel = 4.09
	0.0									
	11.03					10.475				K Factor = 3.41
2	11.78	0.874		0.0	10.000	8.672				K Factor = 4.00
to		150		0.0	0.0	0.0				
2A	11.78	0.0787		0.0	10.000	0.787				Vel = 6.30
2A	0.0	1.101	1N	7.0	12.000	9.459				
to		150	1O	5.0	12.000	0.0				
11A	11.78	0.0255		0.0	24.000	0.613				Vel = 3.97
	0.0									
	11.78					10.072				K Factor = 3.71
3	14.19	0.874	1O	3.0	10.000	12.585				K Factor = 4.00
to		150	1N	7.0	10.000	-4.331				
10	14.19	0.1110		0.0	20.000	2.221				Vel = 7.59
	0.0									
	14.19					10.475				K Factor = 4.38
4	14.48	1.101	1O	5.0	12.000	13.104				K Factor = 4.00
to		150	1N	7.0	12.000	-4.331				
11	14.48	0.0375		0.0	24.000	0.899				Vel = 4.88
	0.0									
	14.48					9.672				K Factor = 4.66
10	25.22	1.101	1O	5.0	3.000	10.475				
to		150		0.0	5.000	0.0				
12	25.22	0.1044		0.0	8.000	0.835				Vel = 8.50
	0.0									
	25.22					11.310				K Factor = 7.50
11	14.48	1.101		0.0	10.680	9.672				
to		150		0.0	0.0	0.0				
11A	14.48	0.0375		0.0	10.680	0.400				Vel = 4.88
11A	11.78	1.101	1O	5.0	6.000	10.072				
to		150		0.0	5.000	0.0				
12	26.26	0.1125		0.0	11.000	1.238				Vel = 8.85
12	25.22	1.394		0.0	5.750	11.310				
to		150		0.0	0.0	0.0				
13	51.48	0.1240		0.0	5.750	0.713				Vel = 10.82
13	-20.66	1.598	2O	16.0	10.000	12.023				
to		150		0.0	16.000	0.0				
23	30.82	0.0247		0.0	26.000	0.642				Vel = 4.93
	0.0									
	30.82					12.665				K Factor = 8.66
13	20.66	1.598		0.0	39.000	12.023				
to		150		0.0	0.0	0.0				
14	20.66	0.0118		0.0	39.000	0.459				Vel = 3.30

Final Calculations - Standard

Residential Fire Protection
Munjoy Heights building D

Page 6
Date 2-21-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
14 to 24	0.0 20.66	1.598 150 0.0118	2O	16.0 0.0 0.0	10.000 16.000 26.000	12.482 0.0 0.306				Vel = 3.30
	0.0 20.66						12.788			K Factor = 5.78
23 to 24	10.16 10.16	1.598 150 0.0032		0.0 0.0 0.0	39.000 0.0 39.000	12.665 0.0 0.123				Vel = 1.63
	0.0 10.16						12.788			K Factor = 2.84
23 to 33	20.66 20.66	1.598 150 0.0118	2O	16.0 0.0 0.0	10.000 16.000 26.000	12.665 0.0 0.306				Vel = 3.30
	0.0 20.66						12.971			K Factor = 5.74
24 to 34	30.82 30.82	1.598 150 0.0247	2O	16.0 0.0 0.0	10.000 16.000 26.000	12.788 0.0 0.642				Vel = 4.93
	0.0 30.82						13.430			K Factor = 8.41
33 to 34	20.66 20.66	1.598 150 0.0118		0.0 0.0 0.0	39.000 0.0 39.000	12.971 0.0 0.459				Vel = 3.30
34 to 35	30.82 51.48	1.598 150 0.0638	1N	9.0 0.0 0.0	39.000 9.000 48.000	13.430 0.0 3.060				Vel = 8.24
35 to TR	0.0 51.48	2.067 120 0.0274	2E 1T	10.0 10.0 0.0	3.500 20.000 23.500	16.490 19.490 0.645				Vel = 4.92
TR to BR	0.0 51.48	2.067 120 0.0275	1E 1Z	5.0 5.0 0.0	10.000 10.000 20.000	36.625 8.166 0.550				* Fixed loss = 6 Vel = 4.92
BR to UNG1	0.0 51.48	1.92 150 0.0261	1T	10.55 0.0 0.0	60.000 10.550 70.550	45.341 0.0 1.839				Vel = 5.70
UNG1 to TEST	100.00 151.48	8.27 140 0.0002	1T 1G 4F	55.354 6.326 56.936	460.000 118.616 578.616	47.180 4.000 0.103				Qa = 100 * Fixed loss = 4 Vel = 0.90
	0.0 151.48						51.283			K Factor = 21.15