



RESIDENTIAL FIRE PROTECTION, LLC  
 PHONE (607) 946-3473 FAX (607) 946-3474  
 64 DAGGETT HILL ROAD GREENE, MAINE 04236

**GENERAL NOTES**

FF k=XX FIN FLR TO CENTERLINE OF PIPE  
 C k=XX CEILING TO CENTERLINE OF PIPE  
 T J k=TOP OF JOIST TO CENTERLINE OF PIPE  
 B J k=BOTTOM OF JOIST TO CENTERLINE OF PIPE  
 BB k=BOTTOM OF BEAM TO CENTERLINE OF PIPE  
 ELEV k=CIVIL ELEVATION OF CENTERLINE OF PIPE

ALL DIMENSIONS ARE CENTER TO CENTER U/N  
 ALL THREADED PIPE TO BE SCH. 40 BLACK STEEL  
 ALL GROOVED FITTINGS TO BE STD. WT. C.I. BLACK U/N  
 ALL GROOVED PIPE TO BE SCH. 10 BLACK STEEL  
 ALL OTHER PIPING TO BE CPVC PLASTIC  
 ALL OTHER FITTINGS TO BE CPVC PLASTIC

**SYSTEM DESIGN**

A WET PIPE SYSTEM OF AUTOMATIC SPRINKLERS TO BE DESIGNED AND INSTALLED PER NFPA 13R  
 ALL SPRINKLERS TO BE BASED ON LIGHT HAZARD

REVISION NUMBER	DATE	SUBMITTED BY	DATE	TITLE
		DRAWN BY	DATE	
		APPROVED BY	DATE	
		SCALE		
		SHEET NO.		

STANLEY J. CAMIC  
 NICET III - #78855

MUNUOY HEIGHTS  
 79 WALNUT ST  
 PORTLAND, MAINE

SCALE: 1/8" = 1'-0" U/N  
 SHEET NO. 7 OF 7

NO. OF SPRINKLERS: 0  
 NO. OF RISERS: 936  
 CUBIC FT: C14005