

| ERU (Energy Recovery Unit) Schedule |       |          |              |                   |               |              |                   |             |                 |            |                  |                  |             |       |     |       |                         |                       |
|-------------------------------------|-------|----------|--------------|-------------------|---------------|--------------|-------------------|-------------|-----------------|------------|------------------|------------------|-------------|-------|-----|-------|-------------------------|-----------------------|
| QTY                                 | TAG   | OA (CFM) | ESP (IN. WG) | Total SP (IN. WG) | FAN EX. (CFM) | ESP (IN. WG) | Total SP (IN. WG) | OA OPER. HP | OA FAN MOTOR HP | OA FAN RPM | EX. FAN OPER. HP | EX. FAN MOTOR HP | EX. FAN RPM | V/∅   | MCA | MROPD | MANUFACTURER MODEL #    | Service Area          |
| 1                                   | ERU-1 | 850      |              |                   | 850           |              |                   |             |                 |            |                  |                  |             | 208/1 | 5   | 15    | Renewaire HE1XINHECM    | COMMERCIAL 1          |
| 54                                  | ERU-2 | 80 - 150 |              |                   |               |              |                   |             |                 |            |                  |                  |             | 120/1 | 1.5 | 15    | Reversomatic RHRV-C100P | Guest Rooms-Corridors |

| Mini Split Outdoor Units |              |              |              |                       |                       |      |       |      |       |                    |
|--------------------------|--------------|--------------|--------------|-----------------------|-----------------------|------|-------|------|-------|--------------------|
| QTY                      | Tag #        | Manufacturer | Model        | Cooling Capacity BTUH | Heating Capacity BTUH | SEER | V/∅   | MCA  | MROPD | Areas Served       |
|                          | MUZ-FH15NA   | mitsubishi   | MUZ-FH15NA   | 17,000                | 22,000                | 26   | 208/1 | 11.1 | 20    | APARTMENT          |
|                          | MXZ-2C20NAHZ | mitsubishi   | MXZ-2C20NAHZ | 18,000                | 22,000                | 17   | 208/1 | 15.0 | 20    | APARTMENT          |
|                          | MXZ-3CC0NAHZ | mitsubishi   | MXZ-3CC0NAHZ | 28,400                | 28,600                | 18   | 208/1 | 18.0 | 20    | APARTMENT          |
| 1                        | MXZ-8C48NAHZ | mitsubishi   | MXZ-8C48NAHZ | 48,000                | 54,000                | 18.9 | 208/1 | 42   | 50    | CORRIDORS          |
| 1                        | PUY-A12NAH4  | mitsubishi   | PUY-A12NAH4  | 12,000                |                       | 13.8 | 208/1 | 13   | 15    | ELEV. MACHINE ROOM |
| 1                        | MXZ-8C48NAHZ | mitsubishi   | MXZ-8C48NAHZ | 48,000                | 54,000                | 18.9 | 208/1 | 42   | 50    | COMMERCIAL 2 & 3   |
| 2                        | MXZ-8C48NAHZ | mitsubishi   | MXZ-8C48NAHZ | 48,000                | 54,000                | 18.9 | 208/1 | 42   | 50    | COMMERCIAL 1       |

| Electric Heater Schedule |        |         |       |            |              |
|--------------------------|--------|---------|-------|------------|--------------|
| Tag#                     | Type   | KW      | V/∅   | Model      | Location     |
| CUH-1                    | Qmark  | 1.8-4.0 | 208/1 | SSC4008    | North Stair  |
| CUH-2                    | Qmark  | 1.8-4.0 | 208/1 | SSC4008    | North Stair  |
| CUH-3                    | Qmark  | 1.8-4.0 | 208/1 | SSC4008    | South Stair  |
| UH-1                     | Markel | 3.3     | 208/1 | F1FUH03003 | Trash        |
| UH-2                     | Markel | 3.3     | 208/1 | F1FUH03003 | Mechanical   |
| UH-3                     | Markel | 3.3     | 208/1 | F1FUH03003 | Bike Storage |

| Mini Split Indoor Units |            |              |            |                       |                       |      |       |     |       |                     |
|-------------------------|------------|--------------|------------|-----------------------|-----------------------|------|-------|-----|-------|---------------------|
| QTY                     | Tag #      | Manufacturer | Model      | Cooling Capacity BTUH | Heating Capacity BTUH | SEER | V/∅   | MCA | MROPD | Areas Served        |
|                         | MSZ-FH15NA | mitsubishi   | MSZ-FH15NA | 9000                  | 10900                 | 26   | 208/1 | 1   |       | LIVING STUDIO       |
|                         | MSZ-GE06NA | mitsubishi   | MSZ-GE06NA | 6000                  | 7200                  | 21   | 208/1 | 1   |       | ALL BEDROOMS        |
|                         | MSZ-GE15NA | mitsubishi   | MSZ-GE15NA | 14000                 | 18000                 | 21   | 208/1 | 1   |       | LIVING 1 BEDROOM    |
|                         | MSZ-GE18NA | mitsubishi   | MSZ-GE18NA | 17200                 | 21600                 | 19.2 | 208/1 | 1   |       | LIVING 2 BEDROOM    |
|                         | SLZ-KA09NA | mitsubishi   | SLZ-KA09NA | 8000                  | 9000                  | 15   | 208/1 | 1   |       | CORRIDORS, MAIL     |
|                         | SLZ-KA12NA | mitsubishi   | SLZ-KA12NA | 11000                 | 13600                 | 15.4 | 208/1 | 1   |       | COMMERCIAL 2, Lobby |
|                         | SLZ-KA15NA | mitsubishi   | SLZ-KA15NA | 15000                 | 18000                 | 16   | 208/1 | 1   |       | COMMERCIAL 3        |
|                         | PEAD-A42AA | mitsubishi   | PEAD-A42AA | 42000                 | 48000                 |      | 208/1 |     |       | COMMERCIAL 1        |

| Register Grill & Diffuser Schedule |         |       |        |                |           |                      |
|------------------------------------|---------|-------|--------|----------------|-----------|----------------------|
| Tag #                              | Use     | Size  | CFM    | Type           | Neck Dia. | BOD Model # and Make |
| EG-1                               | Exhaust | 6x6   | 40-75  | Ceiling        | 5"        | PRICE 530D           |
| EG-2                               | Exhaust | ?     | ?      | ?              |           | PRICE 530D           |
| SD-1                               | Supply  | 12x12 | 80-150 | Ceiling Lay In | 5"        | PRICE LCMD           |
| SS-1                               | Supply  | 12x12 | 150    | Ceiling        |           | PRICE 530D           |
| RR-1                               | Supply  | 2'    | 200    | Linear         | 8         | PRICE 530D           |



Ramor Mechanical  
P.O. Box 8204  
962 Main Street  
North Jay, ME 04262

89 Anderson Street  
Portland, ME

OWNER  
Redfern Properties  
P.O. Box 8816  
Portland, ME



DATE: 7/3/19  
WORK: SEE DESCRIPTION  
SCALE: NS  
PROJECT NO:  
CAD DWG FILE: M-6.1.dwg  
DRAWN BY: WFS  
CHECKED BY: HHH  
COPYRIGHT:

SHEET TITLE  
**Mechanical Equipment Schedule**

M-6.1

SHEET INDEX OF TOTAL SHEETS