LEGEND

EMG / NL — BODINE EMG. BALLASTED NIGHT LIGHT FIXTURE

2X4 LIGHT FIXTURE (# INDICATES TYPE PER FIXTURE SCHEDULE)

1X4 LIGHT FIXTURE (# INDICATES TYPE PER FIXTURE SCHEDULE, DIAGONAL LINE DENOTES NIGHT LIGHT)

DOWN LIGHT FIXTURE (# INDICATES TYPE PER FIXTURE SCHEDULE)

S — SINGLE POLE SWITCH – MOUNTED 48" AFF TO TOP

S3 — THREE WAY SWITCH – MOUNTED 48" AFF TO TOP

S4 — FOUR WAY SWITCH – MOUNTED 48" AFF TO TOP

SM — MOTION SENSING SWITCH

S HRV — UNIT EXHAUST FAN SWITCH

SPECIALTY OUTLET

GFI RECEPTACLE SUBSCRIPT IS FOR COUNTER HEIGHT OR WP FOR WEATHER PROOF

DUPLEX CONVENIENCE OUTLET 18" AFF TO CENTER EXCEPT AS NOTED

DOUBLE DUPLEX CONVENIENCE OUTLET 18" AFF TO CENTER EXCEPT AS NOTED

J — JUNCTION BOX - SIZED AS REQUIRED

DISCONNECT SWITCH - FUSED AS REQUIRED (DIAGONAL LINE INDICATES FUSED)

ELECTRIC MOTOR CONTROLLER

EXIT LIGHT ATLITE #PNLRU W/LED LAMPS BATTERY BACKUP

EBU - EMERGENCY LIGHT BATTERY UNIT. 120V VOLT AC. BATTERIES TO BE RATED FOR 90 MINUTES FOR CONNECTED LOAD.

TEL/DATA RECEPTACLES (HALF SHADED DENOTES TELEPHONE AND DATA, CLEAR TELEPHONE ONLY, SOLID DENOTES DATA ONLY)

PFB — POWER FLOOR BOX

OS — CEILING MOTION SENSOR

R — RELAY

A — ADA DOORBELL STROBE

D — ADA DOORBELL

AOR — AREA OF RESCUE

GFI	GROUND FAULT INTERRUPTER /W SURGE SUPPRESSOR
EWC	ELECTRIC WATER COOLER
EF	EXHAUST FAN
WP	WEATHERPROOF
PC	PARTIAL CIRCUIT
FBO	FURNISHED BY OTHERS
C	COUNTER HEIGHT (SEE MILLWORK DRAWINGS FOR HEIGHT)
H	HOSPITAL GRADE W/RED FACE AND PLATE. IF GFI, DEVICE TO HAVE SURGE SUPPRESSOR
IG	ISOLATED GROUND OUTLET /W SURGE SUPPRESSOR. ORANGE FACE AND PLATE
ST	MANUAL THERMAL OVERLOAD SWITCH
BD	BUSS DUCT
DTT	DRY TYPE TRANSFORMER
C	

FIRE ALARM SYSTEM

F — FIRE ALARM MANUAL STATION 48" AFF

F — FIRE ALARM HORN AND LIGHT UNIT - MOUNT 80" AFF EXCEPT NO CLOSER THAN 6" TO CEILING. NUMBER DENOTES CANDELA RATING

T — SPRINKLER TAMPER SWITCH

FL — SPRINKLER WATERFLOW SWITCH

S — FIRE ALARM VISUAL UNIT (NUMBER DENOTES CANDELA RATING) 6'8" AFF

S — FIRE ALARM SMOKE DETECTOR "E" SUBSCRIPT DENOTES ELEVATOR RECALL.

S CO — FIRE ALARM SMOKE/CO COMBINATION DETECTOR

ANN. — FIRE ALARM ANNUNCIATOR

FACP — FIRE ALARM CONTROL PANEL

GENERAL NOTES:

1) ALL BRANCH CIRCUITS TO BE TYPE MC CABLE.
2) ALL ELECTRICAL MUST MEET NEC AND LOCAL CODES.
3) TELEPHONE AND DATA WIRING BY OTHERS
4) TEMPERATURE CONTROL WIRING BY OTHERS

DRAWINGS

	E100-1ST FLOOR/ SITE
	E200-SAMPLE UNIT
	E201- UNIT LAYOUT - SECTION A
	E202 - UNIT LAYOUT - SECTION B
	E203 - UNIT LAYOUT - SECTION C
	E204 - UNIT LAYOUT - UNIQUE UNITS
	E205 - ROOFTOP POWER
	E300 - ONE LINE/SCHEDULES

CITY OF PORTLAND MAINE RESURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/17/16

STATE OF MAINE STEVEN JONASON #8468 LICENSED PROFESSIONAL ENGINEER

B·H·Milliken
ELECTRICAL CONTRACTORS

175 ANDERSON STREET
PORTLAND, MAINE
04101
207.879.1877

89 ANDERSON STREET

89 ANDERSON STREET
PORTLAND, MAINE

TITLE: LEGEND

SCALE: -

DATE: 07.03.15

SHEET: E100