Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/17/16

December 15, 2014

RE: 89 Anderson St. Scope of Work

BH Milliken will be installing a new addressable fire alarm system for 89 Anderson St. This will be a 4 story mixed use building with parking, retail space and 53 living units.

The building will be fully sprinkled. The panel will be located in the electrical/mechanical room. The building will have an AES Radio Masterbox and the panel will be monitored via a 24 hour central station of the customer's choice.

Norris Inc. will provide the fire alarm equipment, submittal documents, fire alarm permits, and final connections and testing per City of Portland requirements.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/17/16