

---

**CITY OF PORTLAND**  
**DEPARTMENT OF PLANNING & URBAN DEVELOPMENT**  
389 Congress Street  
Portland, Maine 04101

---

**Inspection Violations**

<b>Owner/Manager</b> CARTER DONALD L		<b>Inspector</b> Peter Merrow	<b>Inspection Date</b> 8/19/2005
<b>Locatation</b> 5 EVERETT ST	<b>CBL</b> 012 J011001	<b>Status</b> Re-Inspect 30 Days	<b>Inspection Type</b> Complaint-Inspection

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
1) 6-108.5	Exterior			Various locations	
<b>Violation:</b> Chimneys, flues and vent.					
<b>Notes:</b> Chimney falling apart, foundation cracked.					
<b>Comments:</b> Need to repoint chimney and foundation					