

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
 389 Congress Street
 Portland, Maine 04101

Inspection Violations

Owner/Manager MALONSON DONALD R		Inspector Peter Merrow	Inspection Date 09/02/2005
Location 22 WINTHROP ST	CBL 012 J012001	Status Re-Inspect 30 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.5	Exterior			roof	
Violation: Chimneys, flues and vent.					
Notes: Missing bricks and mortar from chimney					
Comments: Chimney has missing bricks and morder					